HYDRAULIC NETWORK MODELLING OF THE RAROTONGA WATER SUPPLY SYSTEM COOK ISLANDS

Paula Dawe and Harald Schölzel SOPAC Secretariat

March 2000

SOPAC Technical Report 296

This project has been supported by NZODA, the Canadian organization CUSO and the United Nations through Funding from the Federal Republic of Germany

Table of Contents

EXECUTIVE SUMMARYI		
1. INTRODUCTION1		
1.1 GENERAL1		
1.2 SCOPE OF THE PROJECT1		
2. ACKNOWLEDGMENTS		
3. DEVELOPMENT OF HYDRAULIC MODEL4		
3.1 NETWORK LAYOUT		
3.2 ELEVATION DATA		
3.3 DEMAND DATA		
Commercial, Hotel and Industrial Demand7		
Institutional Demand7		
Agricultural Demand7		
Domestic Demand7		
3.4 USER DEMAND IN TURANGI9		
3.5 CALIBRATION OF THE NETWORK MODEL11		
3.6 MODEL RUNS		
4. CONCLUSIONS AND RECOMMENDATIONS15		
5. REFERENCES		

List of Tables

TABLE 1: A VERAGE DAILY USER DEMANDS FOR RAROTONGA	I
TABLE 2: COMPARISON OF TOTAL DEMAND IN RAROTONGA ACCORDING TO SOPAC AND ADB	I
TABLE 3: TYPICAL DEMAND VALUES PER ESTABLISHMENT FOR RAROTONGA AS DETERMINED BY SOPAC	7
TABLE 4: TOTAL ESTIMATED USER DEMANDS FOR RAROTONGA	8
TABLE 5: ACCOUNTING FOR DIFFERENCES IN SOPAC AND ADB TOTAL DEMANDS	8
TABLE 6: CALIBRATION SCENARIOS FOR THE TURANGI HYDRAULIC MODEL	11
TABLE 7: DESCRIPTION OF MODEL RUN	14
TABLE 8: STATISTICS FROM THE TURANGI ZONE	15

List of Figures

FIGURE 1: HYDRAULIC NETWORK MODEL OF RAROTONGA WITHOUT PROJECT EAST UPGRADES	4
FIGURE 2: HYDRAULIC NETWORK OF TURANGI ZONE	5
FIGURE 3: DIGITAL TERRAIN MODEL OF RAROTONGA	6
FIGURE 4: A GRICULTURAL PLOTS IN A SECTION OF THE TURANGI ZONE	9
FIGURE 5: DEMAND PATTERN FOR THE TURANGI ZONE	10
FIGURE 6: LOCATION OF TURANGI NETWORK LOW PRESSURE END NODE	12
FIGURE 7: PRESSURE VARIATION AT J-189 (END NODE) FOR EXTENDED PERIOD SIMULATION	13
FIGURE 8: VARIATION OF PRESSURE AT TURANGI JUNCTIONS WITH INCREASED DEMAND FACTOR	13

Executive Summary

The following report describes the work involved in creating a working hydraulic model of the Turangi section of Rarotonga's water distribution system. Work was performed both in the Cook Islands in cooperation with the Water Works Department, and at SOPAC offices in Fiji.

Objectives that were achieved during the trip to the Cook Islands include:

- i) a basic familiarity with hydraulic principles, Cybernet 3.0 functions, and distribution system design methods by one member of the Rarotonga Water Works Department.
- ii) a network model of the Turangi section of the Rarotonga water distribution system using data collected by the Water Works Department and other organisations.

The development of the Turangi network model involved the collection of demand, elevation and pipe layout information. In order to determine total water use (or demand) for the entire population of Rarotonga, estimates of domestic, commercial, hotel, industrial, institutional and agricultural demand were made. The following table summarises these results.

Table 1: Average Daily User Demands for Rarotonga

User Type	Average Demand
Domestic, L/d per person	300
Commercial, L/d per establishment	3,835
Hotel, L/d per hotel	13,858
Industrial, L/d per establishment	10,384
Institutional, L/d per establishment	15,792
Agricultural, L/d per plot	3,+400

These estimates are based on metered water use of specific buildings, and typical demand values.

The Turangi model reflects the proposed sectorisation of one of the five zones proposed by the Asian Development Bank infrastructure plan. Where possible, comparisons on numbers found in the ADB report were made with SOPAC-derived values, the most obvious being user demand. As can be seen in the following table, our total demand was significantly higher than the one put forth by the ADB.

Table 2: Comparison of Total Demand in Rarotonga According to SOPAC and ADB

User Type	SOPAC Estimated Demand (m3/d)	ADB Estimated Demand (m ³ /d)
Domestic	3,167	2,403
Commercial	1,066	602
Hotel	1,813	899
Industrial	424	795
Institutional	362	361
Agricultural	5,241	3,775
Total	12,073	8,835

Besides evaluating total demand for Rarotonga, water use in the Turangi zone also had to be calculated. To do this, individual demands from houses, commercial properties, plantation hose cocks, etc were aggregated at certain spots or junctions. The individual demands were either based on known metered demands or typical demands for certain types of properties such as schools, office buildings and stores. In the case of agricultural demand, water use

was calculated on a per-area basis. This required estimating the total area of agricultural plots in the Turangi zone.

As flow throughout the system is not constant over time, some kind of demand pattern for the Turangi system had to be determined. This was done looking at daily flow records of water being drawn from the Turangi intake. The pattern indicated that there was a peak in water use at around 7:30 am and 4 pm. Minimum water use occurred at 3 in the morning.

With all the input data as complete and as accurate as possible, calibration of the model was then performed to try and get the model to reflect measured values as they occur in the real system. The measured flow and pressure data used to evaluate the model flow and pressure results were collected by the Water Works Department. This data, collected within the past two years, reflects the isolation of the Turangi zone from the rest of Rarotonga's distribution system. The model only produced results close to the measured flow and pressure data when water use was increased by almost 3 times the estimated user demand. This translates into approximately 65% of water in the Turangi zone being unaccounted for or lost.

The only model run performed with the calibrated model was with the Matavera and Tupapa intakes taken offline, leaving the Turangi intake to supply the entire zone. This is how the zone would operate according to the ADB Infrastructure Development Report. Results indicate that the Turangi intake will not be able to supply the entire demand from this zone, as the Turangi stream simply cannot supply this amount of water. The resulting pressures throughout much of the system will also be too low for proper water distribution.

1. Introduction

1.1 General

Rarotonga's water distribution system supplies water from 12 intakes located high up in the interior of the island to a population of just over 10,000 spread around the coast. The distribution system is entirely gravity fed and operates generally at high pressures. The current water supply system is under stress, presumably from excessive and often irresponsible use by the population, and from leakage problems throughout the distribution network. Estimates of leakage range from 30-50% of the water drawn from the intakes. Water is also provided free to users in Rarotonga.

Many studies have identified the excessive demand through real consumption and water losses as the major problem of Rarotonga's water supply system. None of the suggested improvements such as water pricing as a demand regulating measure have yet been implemented.

Currently, discussions and assistance provided by the Asian Development Bank (ADB), World Health Organisation (WHO) and SOPAC that emphasised the importance of water tariffing seem to have lead to a change in political and public perception of the matter. A major public concern about water tariffing was the public notion that the Water Works "could make huge profits at the expense of its customers without improving the service". In order to be able to provide the desired service improvements Water Works has established alliances with WHO and SOPAC to drastically improve services. SOPAC provides Technical Assistance (TA) to train staff in asset managing systems (GIS) and hydraulic network modelling. WHO concentrates on leak detection and operational management (sectorisation, zone metering etc.) of the water supply system.

To implement the necessary hardware for service improvement Water Works has in the past relied mainly on New Zealand Official Development Assistance (NZODA). "Project East" was such an initiative implemented by the Water Works Department to provide upgrades to the north eastern part of Rarotonga's water distribution system ie. in the Turangi zone. The project clearly demonstrates the capability of Rarotonga's Water Works Department to undertake their water supply system upgrading work.

1.2 Scope of the Project

The work described in this report was performed during two separate visits to the Cook Islands from May 26th to June 1st 1999 and December 1st to the 11th, 1999 in cooperation with the Rarotonga Water Works Department.

The purpose of the visits was to provide hydraulic training to selected members of the Water Works staff including use of the Cybernet hydraulic modelling software, and to develop a hydraulic network model of Rarotonga's water supply system. Cybernet is a trademark software application of Haestad Methods.

The hydraulic training that was performed was aimed at enhancing the design capabilities of Water Works staff. Modelling tools such as Cybernet can be used to simulate the operation of distribution networks, in order to see how they will operate under different conditions. It is good practice for water works departments to develop a network model of their system.

Hydraulic modelling of Rarotonga's water supply system will provide:

- information on how the distribution system operates
- an inventory of the type, size and layout of the pipe network
- > an indication as to whether design demands can be met by the existing system
- Iocation of possible problems in the network ie. high/low pressure areas, leaking pipes

> knowledge on how proposed updates to the distribution network will operate

The staff member of the Water Works Department selected for hydraulic and Cybernet training was Adrian Teotahi. This choice of staff proved to be fortunate as he exhibited a high level of computer competence, an extensive knowledge of Rarotonga's existing distribution system, and an ability to absorb the information that was being imparted to him. More importantly, he was able to recognise the need for systematic and planned hydraulic modelling of Rarotonga's water distribution system, and seemed enthusiastic to get on with the work. Topics covered during the tutorials can be found in Appendix A.

The report also reflects the evaluation of the work done by other agencies, as well as new information that has been recently generated by the Water Works, WHO, ADB and SOPAC. It describes the steps for building a network model and the underlying details involved in doing so.

Though data has been gathered and summarised for the entire water supply system, this report focuses only on the modelling work of the Turangi Area ("Project East"), mainly because of time constraints and training considerations. However, the background information will enable Water Works, with assistance from SOPAC, to create similar networks for the remaining parts of their distribution system within the next six months. All the information and data collected for this report will be made available to the Rarotonga Water Works Department.

This report is intended to serve as a manual for the Water Works to proceed with the work already begun, therefore it describes relations and assumptions with more detail than generally considered necessary for a Technical Report.

2. Acknowledgments

The SOPAC Secretariat would like to thank NZODA for their financial support as part of its Water Demand Management project. The authors wish to thank all staff of Rarotonga's Water Works Department for their support and cooperation during the trip, especially Mr. Ben Parakoti, (Director) Adrian Teotahi as well as Patrick Tangapiri.

3. Development of Hydraulic Model

During a previous trip to the Cook Islands in May 1999 SOPAC Water Resources staff created a Cybernet model of Rarotonga's Water distribution system. The layout (Figure 1) of the pipe network followed the pre-Project East Master Plan and contained only roughly estimated demand information.



Figure 1: Hydraulic Network Model of Rarotonga without Project East Upgrades

To create a more complete and updated model various sources of information already in the possession of the Water Works Department had to be located and reviewed. This included information on updates to the pipe network layout, information on different types of user demand in Rarotonga, and elevation data.

3.1 Network Layout

The modelling that was eventually performed did not include all of Rarotonga, only the Turangi Water Supply Zone as set out in various studies (ADB, 1999; WHO 1997; Parakoti, 1998) that recommend sectorisation of the water supply system. The Turangi zone can be seen in Figure 2.



Figure 2: Hydraulic Network of Turangi Zone

This area was targeted for the following reasons:

- In order to show members of both the Water Works Department and the ADB proposal steering committee how such zoning of the water supply system might work.
- ii) To provide a useful example to members of the Water Works Department of how Cybernet as a tool could be used to enhance their capabilities and effectiveness as a department.
- iii) To model updates to the distribution system performed during Project East.

The upgrading work performed during Project East included the laying of a 24 km sub-main from Avarua town in the north to Avana stream in the east on the opposite side of the road from the ring main that goes around the entire island. The purpose of this upgrade was to reduce the demand on the distribution system near the supply intakes, and to increase pressure and consequently supply in areas far from the intakes (Parakoti, 1998). A review of pipe size and materials in the network was also performed.

3.2 Elevation Data

Previous work done within the Ministry of Works, Environment, and Physical Planning (MOWEPP) resulted in the digitization of a 50-ft contour map of Rarotonga. This AutoCAD file, however, had no elevation data associated with each contour line.

To format this data into useable information, each contour line had to be turned into a separate polygon and assigned its appropriate elevation. The data was then imported into MapInfo where peak elevations, and 5 m contour lines around the coast were inserted. The end result was a Digital Terrain Model (DTM) of Rarotonga with associated elevation information held in MapInfo tables. The DTM can be seen in Figure 3.

5



Figure 3: Digital Terrain Model of Rarotonga

Work done on the existing Rarotonga network model did not include any information on the elevation at different junctions. In order to input this information into Cybernet, the existing information in the hands of the Water Works Department had to be formatted into MapInfo tables. With this task accomplished, a database connection was established through Microsoft Access to transfer the appropriate junction elevations to Cybernet.

3.3 Demand Data

Over the past 9 years, flow data from the intakes, and meter information from specific users has been collected in a haphazard fashion. Existing information included:

- Hardcopy flow records from several intakes from 1992
- Summary information collected by a French WS project on domestic demands from 1993-94
- Summary information collected by the consultants WMI (ADB, 1999) on hotel, commercial, institutional, and agricultural demands from 1992-94
- Data from commercial, industrial, institutional, and hotel meters collected by the Water Works Department from 1993-94 and from 1996-97

First of all, meter records had to be formatted from bulk volume (L) to actual flow rates (m^3/d) and then average demand values for these extended-period records were worked out. Secondly, the records were divided into different user types: commercial, hotel, industrial and institutional. Then averages for each type of user were calculated.

Commercial, Hotel and Industrial Demand

A demand value in litres per second per establishment was worked out for commercial, hotel, and industrial use based on the collected meter records. However, it was felt that the two metered records that qualified as institutional demands did not offer a representative demand value. These records can be found in Appendix B, Tables 1-5.

Institutional Demand

Using 1996 census information on the number of people who attend church, attend university or schools, are employed by government, and are inmates in prison - institutional demands were estimated. Typical demands in L/d per unit were taken from Tchobanoglous & Schroeder, 1987. From these estimated values and the metered hospital demand, a composite institutional demand of 0.18 L/s per establishment was determined.

Agricultural Demand

Agricultural demand was estimated using two different methods. Consumptive use of water by crops was estimated using the empirical Blaney-Criddle equation. This equation takes into account climate, temperature, solar radiation, as well as plant species, and calculates the theoretical amount of water a crop will need to survive. Water consumption by individual crops was estimated theoretically to be 2655 m³/d. Previous estimates of agricultural demand ranged from 3220-18000 m³/d (ADB 1999). The value calculated turned out to be unrealistically low and another approach was applied.

The value for agricultural demand produced by the French consultants in 1992 was 0.04 L/s per plot, and was the average for two locations only. It was also the only metered information on agricultural demands available for Rarotonga. Census information reported that 60% of households in Rarotonga were engaged in agricultural activity. Assuming each such household had at least one plot of land, a more appropriate agricultural demand of 5241 m³/d was determined. It is of interest to note that the amount of water generally being used for irrigation is greater than the water requirements of the individual crops according to these estimations. Calculations for agricultural demand can be found in Appendix B, Table 6.

Domestic Demand

Domestic demand data previously collected for Rarotonga ranges from 150-463 L/d per person (ADB 1999). Based on this range and the opinion of people in the Water Works Department, a domestic demand of 300 L/d per person was chosen. A summary of average demand values can be seen in Table 3. It should be noted that average demand is a flat rate, while real demands vary throughout the day as people use more water at certain times (7 in the morning) and less at others (3 in the morning).

Table 3: Typical User Demand Values Per Establishment for Rarotonga as Determined by SOPAC

User Type	Average Demand	Average Demand
	(L/S- unit)	(L/d- unit)
Domestic, per person	0.014	300
Commercial, per establishment	0.044	3,835
Hotel, per hotel	0.16	13,858
Industrial, per establishment	0.12	10,384
Institutional, per establishment	0.18	15,792
Agricultural, per plot	0.039	3,400

Using metered information and typical demand values for certain types of users, an estimation of total demand for Rarotonga was also produced. Calculation for this can be found in Appendix B, Table 7. Numbers for certain types of establishments (eg. bakeries, petrol stations, construction companies, schools) were counted from the Rarotonga Yellow

Pages. These counted values represented approximately half of the commercial and industrial establishments present in Rarotonga according to te Aponga (Rarotongan Electricity Authority) billing records. Knowing by what percent the commercial and industrial demands were out, an appropriate scaling factor was applied to correct these values. Hotel demands were separated into small and large hotel demands, a small hotel being taken as a hostel or motel with a demand of less than 5 m³/d per hotel. Total domestic demand was based on census population information. Institutional and agricultural total demands were determined as described above.

Table 4 shows the estimated water use for Rarotonga and the ADB proposal estimates.

User Type	SOPAC Estimated Demand (m3/d)	ADB Estimated Demand (m3/d)
Domestic	3,167	2,403
Commercial	1,066	602
Hotel	1,813	899
Industrial	424	795
Institutional	362	361
Agricultural	5,241	3,775
Total	12,073	8,835

 Table 4: Total Estimated User Demands for Rarotonga

The differences in these estimates can be accounted for in the following table.

User Type	SOPAC Estimated Demand	ADB Estimated Demand
Domestic	 Using 300 L/person/day Based on recommendation of Ben Parakoti, Director of Rarotonga's Water Works 	 Using 240 L/person/day Based on ranges from French metering program, between 150-300 L/p/d
Commercial	 Lumping together similar establishments and using either an average metered demand or a typical demand value Using ten records from 93-97 	 Using fixed rate of 1600 L/d for water use for all commercial properties Based on average meter readings for 3 months (Oct-Dec 96)
Hotel	 Working out average demands for small and big hotels from meter records, and knowing the total number of hotels Using ten records from 93-97 	 Using 700 L/d for large hotels and 300 L/d for small hotels Based on average meter readings for 3 months (Oct-Dec 96)
Industrial	 Lumping together similar establishments and using either an average metered demand or a typical demand value Using ten records from 93-97 	 Using fixed rate of 15 000 L/d for water use for all industrial properties Based on average meter readings for 3 months (Oct-Dec 96)
Institutional	 Using typical and metered demands for different institutions Using ten records from 93-97 	 Estimated based on school, hospital, prison and government population
Agricultural	 Based on average meter readings from two agricultural plots and the percent of population involved in agricultural activity 	 Based on crop water requirements

Table 5: Accounting for Differences in SOPAC and ADB Total Demands

Total average yield from the 12 intakes supplying Rarotonga's distribution system, according to the ADB proposal report, is 18 300 m³/d. The term yield is in this case ambiguous, and can either be interpreted as total flow in the intake streams, or as user demand - the portion of water taken from the steam for use in Rarotonga's water distribution system. If the former is the case, streamflows are not very useful data.

3.4 User Demand in Turangi

In a network model, junctions are nodes where water can leave the network to satisfy consumer demands or where water can enter the network as an inflow. Generally, junctions occur at pipe intersections and connections.

To create a more accurate representation of demand in the Turangi model, flows were disaggregated to individual junctions in the network. To do this, the location of each junction was synthesized onto the Census '96 comprehensive map of Rarotonga that details each building on the island. The number and type of user associated with each junction could then be counted. From the detailed Census information, flow data from metered locations could be input directly into the appropriate junctions and more accurate estimates of demand for other establishments could be determined based on similar known or typical demands. For example, metered information on water usage at the Enuakura Petrol Station was used for each petrol station. Typical demands were in litres per unit per day, and so some estimation of the unit - either employee, customer, parking space, seat, patient, or student was required. This information can be located in Appendix C, Table 1.

In order to include a meaningful agricultural demand at each junction, several steps had to first be performed. Using the composite satellite image of Rarotonga's coast, specific agricultural plots could be picked out, and their area determined using MapInfo. The following figure shows one such section of the Turangi zone.



Figure 4: Agricultural Plots in a section of the Turangi Zone

Although the coastal image did not provide complete coverage of the island, complete agricultural demand for some junctions could be determined. For junctions that were not completely included in the coastal image, nearby plantation areas were picked off the 1:25000 Map of Rarotonga (Department of Survey and Land Information-NZ, 1994). Each plantation counted from the map was assumed to have the median area of the agricultural plots determined using MapInfo.

To determine agricultural demand, the total area of land used for planting was summed up for each junction. Using the metered agricultural demand value of 0.04 L/d per plot, and assuming an average plot area is the median value of 1692 m², usage was then calculated on a per area basis. These calculations can be found in Appendix C, Table 2. Agricultural demand was then added to the combined domestic, commercial, institutional and industrial demand.

In order to get some idea of how accurate this area-based agricultural demand method of determination was, a comparison of agricultural areas was made. The total area of agricultural plots in Rarotonga according to the Department of Agriculture was 728 460 m² (ADB, 1999). The area determined for this report was 744 700 m², a difference of 2%. This information can be found in Appendix C, Table 3.

A comparison of population in the Turangi Zone was also performed as a check on the validity of some of the information input into the model. Using Census District information compiled in MapInfo, the Turangi population was determined to be 4068. From the total number of houses associated with each junction, and knowing that on average there are 4.1 residents per household according to the Cook Islands Census of Population, an alternate population estimate of 4022 was determined. These two estimates are within 1% of each other. Calculations for this can be found in Appendix C, Table 4.

A combined-user demand pattern for the Turangi Zone was determined using the hard copy flow records from 1992. Since the demand pattern was derived from the source, it is assumed that it behaves as a composite of individual variations in domestic, commercial, hotel, industrial, institutional and agricultural demands. This assumption can be made because for all practical purposes variation at the source represents such a universal pattern. Cybernet cannot have different demand patterns for each user type, and so a universal pattern is required. The demand pattern can be seen below in Figure 5.



Figure 5: Demand Pattern for the Turangi Zone

To create the pattern, one flow record for each day of the week was taken over the 3-month period records were kept. These daily flow variations were then averaged, a daily average was found, and the demand pattern determined. The Turangi demand pattern was then input into the Cybernet model. Calculations for the demand pattern can be seen in Appendix C, Table 5.

3.5 Calibration of the Network Model

The hydraulic model is a simplified version of a real life system. In the real world demand is not confined to certain junctions, but is dispersed to many individual users over the entire length of the pipe. Calibrating the network model then becomes very important to see if actual pressure and flow values in the distribution system are being simulated accurately or not. Modellers call calibration the process where the idealized model is altered and varied so that it matches real world values. In the case of the Turangi model, electronic records from 1996 to the present were reviewed and used to calibrate the model.

Flow and pressure records prior to the updates performed in 1998 with Project East were discounted as they would not reflect the present day circumstances. The records also had to reflect the situation where the Turangi system is isolated from the rest of Rarotonga's distribution system. The isolation of the Turangi system, as layed out in this model, did not occur till 1998. However, records from 1996 were still used from the non-isolated system, as this was the only information available for calibration.

Firstly it was found that the calculated demand of 27 L/s did not reflect actual values from the real world system. Flows from the Turangi and Tupapa intakes were less than recorded average measured flows, and water was modelled as flowing back up into the Matavera intake. As well, pressure values throughout the system were too high – not less than 550 kPa. For conversion purposes, 1 kPa is equal to approximately 10 cm of water or pressure head.

To calibrate the model, different factors of pipe roughness and demand were tried. A fixed value of 1.5x the pipe roughness was found to be appropriate and was used for each calibration scenario. Roughness is just a numerical constant used to reflect the age of the pipes- the older they are, the less efficiently water traverses through them.

Different factors of demand were determined based on leakage percentages from the system. Table 6 lists the different demand factors used and the corresponding percent of water unattributed to actual demands lost from the system.

Demand Factor	Percent of Total Demand that is Unattributed to Actual Demands (%)	Total Demand from Turangi System (L/s)
1	0	27.2
2.34	57.3	63.7
2.8	64.3	76.2
3.1	67.7	84.4
3.51	71.5	95.7

Table 6: Calibration Scenarios for the Turangi Hydraulic Model

To measure how accurate each demand scenario came to representing the real Turangi distribution system, model pressures, and flows from the intakes were compared to actual values. These actual values were collected from 5 pressure points within the system for which data is regularly recorded, and from 5 locations where pressure readings had been taken on Sept 3, 1996. Minimum and maximum pressure ranges were used to compare the modelled pressure, and average and maximum flow ranges to compare the modelled flow. If the modelled flow or pressure fell within these ranges, the percent difference between the

real life and modelled value was set to 0%. Otherwise, the percent difference was calculated as the minimum difference between the measured values and the one produced by the model. Summaries of each calibration scenario can be found in Appendix D, Table 1.

2.34 times the calculated Turangi demand produces 63.7 L/s, the average total flow from the Tupapa, Matavera and Turangi intakes. Using this demand factor, flow from the Tupapa intake was not within the average to maximum flow ranges. Pressures throughout the system were also found to be high, with differences in real and modelled pressures ranging from 0 to 98%.

2.8 times the accounted-for Turangi demand produces modelled flows from each intake that are within the average to maximum range. Pressures for each of the 5 pressure points are within range, but were from 48 to 77% higher than recorded values for the other 5 locations.

During extended-period simulation for this scenario, pressure head at the junction farthest from the intakes (towards the end of the airport runway, see Figure 6) approaches 0 during times of peak demand. For demand factors greater than 2.8x, pressure becomes negative at the two farthest nodes, J-189 and J-190. Although pressures below atmospheric have been observed in Rarotonga's system, the model does not accurately represent this. When pressure somewhere along a pipe network hits zero, the driving force that impels water to flow through the pressurised pipe system no longer exists at that point. There is no flow through that pipe, and demands connected to that pipe are not met. This lowers the total demand from the intake, but the model doesn't reflect this, or the fact that demands at these end nodes, where pressures are negative, are not being met.



Figure 6: Location of Turangi Network Low Pressure End Node

3.1 times the accounted-for Turangi demand also produces flows that are within the average to maximum flows from the 3 intakes. Pressures within the system are also more accurate, with errors only ranging from 37-61% from actual recorded values at the 5 locations. However, running an extended period simulation, results in negative pressures at the two end nodes. Figure 7 illustrates this problem for J-189 during extended period simulation.



Figure 7: Pressure Variation at J-189 (End Node) for Extended Period Simulation

3.51 times the accounted-for Turangi demand produces 95.6 L/s, approximately the maximum total flow from the Tupapa, Matavera and Turangi intakes. With this demand factor, modelled flows from the Turangi and Matavera intake exceed the maximum-recorded flows from these intakes, but by less than 10%. Pressures from the 5 locations are also improved from between 2-38% error from the recorded values. However, even during a steady-state simulation, pressures at the two end nodes were negative.

The following Figure 8 illustrates how model pressures more closely match actual measured pressures as the demand factor was increased. Appendix D contains maps that show flow and pressure distribution throughout the Turangi Zone for selected demand factors.



Figure 8: Variation of Pressure at Turangi Junctions with Increased Demand Factor

The calibration scenario using the 2.8 demand factor most closely matches what has been observed in the actual distribution system. For this scenario, flows from the 3 intakes were within reasonable ranges, as were pressures from the 5 regularly-recorded pressure points. At no time during extended-period simulation did pressures fall below atmospheric pressure, even at the two end nodes. Also, even though the modelled pressures for the 5 locations were not as accurate as the 3.1x and 3.48x demand factors, they were still reasonable. In calibrating the model, it was more important that flows from the intakes matched.

It is highly probable that there was already inherent error in the pressure readings for these 5 locations. For one, the readings are from 1996, before both the Project East updates and the isolation of the Turangi zone. This means that these pressure readings do not exactly reflect the system as it is modelled. Another reason for this inherent error is that the readings were taken from convenient locations above ground-fire hydrants and building hose cocks. Pressure in the model represents the pressure in the actual pipe. This results in a potential 1-2 m error in pressure head depending on how far beneath the ground the pipe is buried.

3.6 Model Runs

The calibrated Cybernet Turangi model was run for only one situation in which the Turangi intake supplies the entire zone by itself. The ADB Urban Infrastructure Report proposes that the Turangi Zone, as modelled in this report, be supplied solely by the Turangi intake, taking the Matavera and Tupapa intakes offline. The different scenario parameters, and the rationale behind running such a scenario is provided in Table 7.

Table 7: Description of Model Run

Cy	vbernet Run	Rationale
•	2.8 x Demand	The most accurate calibration of the Turangi
•	Fixed demand pattern	model was for 2.8x the calculated demand.
	Without Matavera and Tupapa Intakes	Knowing this is as close to the real life system as the Turangi model can get, inflows from the Matavera and Tupapa Intakes were taken out to see how the system proposed by ADB would behave.

Several interesting points arose from this model run. Firstly, the maximum real-world recorded flow from the Turangi intake was 36.9 L/s. It is not possible for the Turangi intake alone to meet the current total demand of 76.2 L/s for this zone. This flow rate results from the model calibration and from recorded flow at the three intakes.

Secondly, as the model assumes that the source can supply whatever demand is required of it, the total demand was taken from the Turangi intake. This resulted in low pressures throughout the network, and negative pressures at certain nodes. Within a short distance of the intake, pressures in the distribution system fall below 150 kPa, which is the minimum pressure required for adequate distribution in a typical system (McGhee, 1991). The result is that a flow of 76.2 L/s could be provided only if the pipe works were upgraded.

A map showing flow and pressure distribution throughout the Turangi zone for this model run can be found in Appendix D.

4. Conclusions and Recommendations

As with any kind of modelling, the results produced are only as good as the information being input into the model. Of the three different data inputs to the model: demand, elevation, and layout of the distribution system a different value of quality can be assigned to each. Layout and elevation information is considered to be very accurate; demand data less so.

A considerable amount of estimation was involved in determining the various junction demands. Domestic, commercial, hotel, industrial, institutional and agricultural demands were all calculated making various assumptions which include the following:

- demand from an unmetered property could be estimated using a demand from a similar type of metered property
- numbers of individuals at schools, working in offices, shops, etc. are correct
- agricultural demand based on only 2 metered plots, is representative of agricultural demand throughout Rarotonga and for all types of crops
- domestic demand is representative

Some statistics of interest that came out of this analysis are listed in Table 8.

Table 8: Statistics from the Turangi Zone

Description	Percentage, %
Percentage of Rarotonga Population in Turangi Zone	38.1
Percent Accounted for Turangi Demand is of Total Rarotonga Demand	19.5
(using high estimate)	
Percent Calibrated Turangi Demand is of Total Rarotonga Demand (using	54.5
high estimate)	
Percentage of Rarotonga Agricultural Plots in Turangi Zone	39.3
Percentage of Total Rarotonga Commercial and Industrial Premises in	30.8
Turangi Zone (using total te Aponga billing records)	

The Turangi model performed closest to the real-world situation with calibration factors of 1.5 x the pipe roughness and 2.8 x the accounted-for baseline Turangi demand. All other calibration scenarios either resulted in unacceptable flow or pressure values that did not reflect collected real-system values.

The only model run performed was to see how the Turangi distribution system would operate when being supplied solely by the Turangi intake. It was found that it would be impossible for the Turangi intake to meet the total demand required for this zone. Pressures throughout much of the system were also found to be lower than required in typical distribution systems.

According to the 1997 Second Water Utilites Data Book (McIntosh, et.al. 1997), a Consumer Survey came up with the following findings for Rarotonga:

- 80% claimed to have a 24-hour water supply
- 27% said their water pressure was low
- 55% said they had experienced a water-supply interruption in the month prior to the survey

The Utility Profile also noted that from 1992 to 1996, unaccounted-for water had increased to 70%. This unaccounted-for water they attribute mostly to leaks in household plumbing systems and agricultural use in residential connections.

All of the above findings from the Utilites Data Book support results produced in the calibrated Turangi model. The model was found to operate effectively using a demand that

included 64.3% unaccounted-for water as opposed to 70%. Areas of low pressure were located at the end of the Turangi distribution system in the airport area, where if total demand in the system were high enough, pressures would fall below atmospheric. Such an occurrence during times of peak flow would effectively interrupt water supply.

When pressures in a pipe system are below atmospheric pressure, there is the risk of creating a vacuum where water can be drawn from the ground into the pipe. This type of inward leakage into the pipe can potentially draw contaminants from septic tanks into the water distribution system (Peralta, 1997). Such situations are undesirable and have to be avoided. The area towards the end of the airport runway is at risk for this kind of problem. System upgrades to this portion of the Turangi system should be considered.

With respect to the ADB urban infrastructure proposal, this report raises serious questions as to the technical feasibility of the system proposed. The Turangi zone, supplied by the Turangi intake alone could probably work if demand were lowered. However, there is no discussion of how to effectively lower demand in the Turangi zone in the ADB report. Upgrades are proposed to all areas of the network that were neither upgraded in 1992 by WMI nor in 1998-99 during Project East. Upgrades would definitely be required if the Turangi zone were to function as suggested in the ADB report and most probably to a greater degree than considered in the report.

It is recommended that further work in developing hydraulic models of Rarotonga's water distribution system be performed. To facilitate this, a list of tasks to be performed by the Rarotonga Water Works Department, with assistance from SOPAC, has been included in Appendix E. This further work builds upon the modelling already performed in this report.

5. References

- Asian Development Bank. 1999. Cook Islands Urban Infrastructure Project Preparatory Technical Assistance.
- Cook Island Statistics Office. 1996. Cook Island Census-Map of Rarotonga.
- Cook Islands Statistics Office. 1996. Census of Population and Dwellings.
- Department of Survey and Land Information, Wellington, New Zealand. 1994. Map of Rarotonga, Cook Islands.
- Farley, Malcolm, Bull, G., 1999, WHO Mission Report Cook Islands, 28 October-19 November.
- Farley, Malcolm, Dakin, M., 1997, WHO Mission Report no. RS/97/0627– Cook Islands, 26 October- 21 November.
- McGhee, Terence J. 1991. Water Supply and Sewerage, 6th ed. McGraw-Hill Inc. New York.
- McIntosh, Arthur C., Yniguez, Cesar E. 1997. Second Water Utilities Data Book- Asian and Pacific Region. Asian Development Bank.
- Parakoti, Ben, 1998, Project East Upgrades, MOWEPP
- Peralta, G. L.1997. WHO Mission Report no. RS/97/0627 Cook Islands. 13-25 October.
- Tchobanoglous, G., Schroeder, Edward D. 1987. Water Quality. Addison-Wesley Publishing Co. Don Mills, Ontario.

Appendix A: Hydraulic Tutorial Notes

Hydraulic Training

The training provided was spread out over 6 afternoons. By date, the following topics were covered:

Dec $2 \rightarrow$ Quantity of Water Supply

- Quantity of consumption
- Factors effecting water demand
- Types of users
- Variation in use
- Dec $3 \rightarrow$ Introduction to Cybernet Version 3.0
- Dec $6 \rightarrow$ Basic Hydraulics
 - Energy principle
 - Bernoulli's Equation
 - Head loss
- $\mbox{Dec 7}{\rightarrow}$ Collection, Distribution and Operational Elements
 - Pipes, valves, storage
 - Dead ends, high points, low points and water hammer
- Dec $8 \rightarrow$ Design of a Distribution System
- Dec $9 \rightarrow$ Typical Values in the Design and Operation of a Water Distribution System

Part 1

Purpose of Water Distribution systems:

to convey some quantity of water to the individual users

Step 1- Estimating the level of water consumption

- the amount of water you have to supply determines how big your distribution system will • have to be- eq. pipe size
- in order to estimate future water use, you have to estimate the future population you are • going to be supplying

Things that increase (-) or decrease (-) water usage:

- population- more people use more water •
- *climate* people use more water in drier, hotter climates (eg. watering gardens) •
- economic level- rich people use more water than poorer people •
- population density- areas where you have high concentrations of people living have a • lower water demand (eg. in apartment buildings, don't have to water lawns)
- industry- industrial demands tend to be high, but it depends on the type of industry •
- cost- people who pay for their water use less •
- pressure- distributions systems that operate under high pressures use more water •
- quality of supply-people use less water if the quality of that water is poor •
- *culture* some cultures use more water than others (eq. keeping pigs uses a lot of water)

Different types of users:

- domestic
- commercial (stores, bars, restaurants, hotels)
- industrial (airports, factories) •
- institutional (government buildings, schools, hospitals, prisons) •
- agricultural

Total Consumption = domestic use + commercial use + public use + loss and waste

Water consumption varies during the:

- *year* highest during the dry season •
- dav- highest around 7am in the morning when people getting up and showering, lowest from 2-4am in the morning when people are asleep



24

0.8

The demand pattern is simply:

flow average_flow

<u>Part 2</u>

Principle of Conservation of Energy:

• Energy can neither be created or destroyed, but can be changed from one form to another

Head (m) = Energy (J)

Bernoulli's Equation:

- Basically an energy balance from one point in a hydraulic (water distribution) system to another
- Pressure Head: $\frac{P}{g}$ Pressure is what makes pipes special \rightarrow pressurized closed conduits
- *Elevation Head*: z Same as Potential Energy
- Velocity Head: $\frac{v^2}{2g}$ Same as Kinetic Energy or energy due to motion
- Head Loss: h_L Energy lost to friction as water moves along the pipe

Minor losses \rightarrow occur in pipe fittings, bends, valves, meters, transitions, reducers, etc.

 $\mathsf{Pumps}{\rightarrow}$ a pump will add head to your system

Hydraulic Grade Line (HGL):

- Sum of pressure head and elevation head
- In water open to the atmosphere (river, lake), the HGL is at the water surface
- The hydraulic gradient is the slope of the hydraulic grade line

Head Loss can be calculated using:

- Darcy-Weisbach Equation (use this one for pipe systems)
- Mannings Equation
- Hazen-Williams Equation

Velocity Profiles in a Pipe:

- Velocity in a pipe is greatest at the centre of the pipe
- Velocity is reduced towards the pipe wall because of friciton
- Velocity of water right at the pipe wall is 0

Note- Look over Cybernet theory bit that was photocopied

<u>Part 3</u>

 $\ensuremath{\mathsf{Pipes}}\xspace \rightarrow \ensuremath{\mathsf{pressurized}}\xspace$ closed conduits

Stresses Acting on Pipes:

- Pressure of water acting on the pipe (remember that the water doesn't want to be in the pipe and is always trying to force its way out)
- Forces caused by changes in the direction of flow within the pipe
- External loads like the weight of dirt on the buried pipe

• Changes in velocity

Water Hammer

- Results from the sudden stopping or slowing of flow in a pipe
- The kinetic energy of the water is transferred to the pipe wall and acts to stretch, deform and burst the pipe
- Can be avoided by closing valves slowly for example

Low Points

- Where the depth of the pipe below the ground surface is great
- High pressures may form at low points in the distribution system
- You want to break the hydraulic gradient at low points with pressure reducing valves (PRV), overflows, auxiliary reservoirs
- Place hydrants at low points in order to drain the distribution lines for maintenance purposes, and to remove sediment

High Points

- Should be kept below the HGL, otherwise you can get negative pressures in pipes which leads to the accumulation of gasses that may block the flow of water through pipes
- Negative pressures in pipes can create a vacuum that will actually suck water from the ground into your pipe→ problem if you are sucking in contaminated water from a septic tank
- Use vacuum, air relief valves, or pressure sustaining valves (PSV) to release air initially in the line or that accumulates over time, or to admit air when the line is being emptied for maintenance purposes

Valves

• Should be located at regular intervals (150-250 m) throughout the system so breaks in the pipe network can be isolated and fixed without disrupting flow to the entire system

Storage Tanks

- Used to equalize supply and demand over the long term or for emergencies such as fire
- Storage tanks placed in areas of high consumption and low pressure, and will act to increase pressure during periods of high use (7 in the morning)
- The tank will refill during the night when consumption is low and pressure high

Dead Ends

- A pipe that just terminates
- Should be avoided since supply is less certain, and lack of flow in the pipe may contribute to water quality problems

<u>Part 4</u>

Design of a distribution system depends on:

- *Topography* since the water supply sources for Rarotonga are located above the level of the water users, no pumping is required → Rarotonga has a gravity distribution system
- Users- how much water people use determines how big your distribution system is going to have to be

Steps in designing a distribution system:

1. Flows to each section of the community must be estimated and designated to individual subareas of your system

- 2. A system of interlocking loops must be laid out→ this ensures continuous delivery of water even if a portion of the system is shut down for repairs
- 3. Flows are assigned to various nodes of the system
- The actual design of the distribution network involves determining the size of the pipes required to ensure appropriate pressures, flows, head losses and velocities in the system under a variety of design flow conditions

Design flow:

- must make sure that the system operates during the worst case scenario→ maximum daily flow + fire flow
- The design of a distribution system is based on the provision of adequate pressure for fire protection at the maximum daily flow, including fire demand

There are many solutions to the design problem of creating a distribution system \rightarrow you must optimise (adjust parameters such as pipe size to achieve the most appropriate pressures at nodes and velocities in pipes) to find the best solution.

Distribution system consists of a network of:

- nodes \rightarrow points of flow withdrawal
- links→ pipes connecting nodes

It is not reasonable to analyse a system up to every house \rightarrow individual flows can be concentrated at a smaller number of points, commonly at pipe (or road) intersections

<u> Part 5</u>

Design Element	Typical Value
Fire Flows (L/min)	1890 \rightarrow min
	$32400 \rightarrow max$
Distance between pipe on/off valves	150-250 m
Velocity in pipes to prevent deposition of	0.3-0.6 m/s
sediment	
Maximum velocity (@ design flow = max	≤1 m/s
daily flow + fire flow)	
Required pressure in distribution system	150-300 kPa
Distance between fire hydrants	60-150 m
Pipe depth in southern climates	~0.75 m
Location of pipes	Along right of way of streets

Appendix B: Demand Data for Rarotonga

Table 1: Commercial, Industrial,	Hotel and Institutional	Demand in Rarotonga
----------------------------------	-------------------------	---------------------

	Dec93- Feb94 (m3/d)	Oct96 (m3/d)	Nov96 (m3/d)	Dec96 (m3/d)	Jan97 (m3/d)	Mar97 (m3/d)	Apr97 (m3/d)	May97 (m3/d)	Jun97 (m3/d)	Aug97 (m3/d)	Average (m3/d)
Airport Authority						15.88		16.76	17.73	45.46	23.96
ANZ Bank											
Building		7.25	14.13	8.10	5.59	3.20	3.27	3.15	6.80	3.00	6.05
Motel	20.40		25.80	16.97	18.18	13.72	18.73	20.76	36.07	22.96	21.51
Ariana Bungalow s		9.38	31 87	18.00	15 73	17 00	16 42	21 67	53 20	24 85	23 12
Ati's Beach											
s	3.26	3.13	4.00	4.03	3.09	4.40	6.42	4.00	6.80		4.35
Audtorium											
water Tank		2.25	6.00	2.90	2.14	3.44	9.15	1.88	3.53	1.62	3.66
Avana											
Marine Condo's	3 51	1.50	4 93	2 10	5 23	1 44	3 15	1 82	5.07	4 54	3 33
B & M	0.01			2	0.20		0.10		0.01		0.00
Heather LTD				0.69	0.59	0.48	0.42	0.30	0.47	0.31	0.47
B & M				0.00	0.00	0110	0.1.2	0.00	0	0.01	0.11
Heather LTD		4.88	16.53								10.70
Blue Pacific Laundry											
LTD	19.05	0.63									9.84
Concrete Structures		0.50	0.07	0.70	1.00						4 75
Cook		0.50	2.07	2.70	1.09						1.75
Island Bottlers I TD	1 51	70 75	33.40	15.03	16.23	14 76		12.45		0 10	21.67
CIDB	1.51	10.13	33.40	13.03	10.23	14.70		12.45		3.13	21.07
Building	1.92										1.92
Cooks Conners Cafe	1.46	0.75	1.73	0.93	0.95	0.84	2.92	2.70	4.60	3.69	2.06
Cooks Conners Shopping											
Complex	2.76	2.00	5.20	2.59	2.41	2.88	0.92	0.94	1.80	1.08	2.26
Cultural Centre	4.13										4.13
Enuakura											
Petrol Station		0.63	1.07	0.62	0.91	0.68	0.69	1.06	0.33		0.75
Flame Tree Restaurant	7.23	8.88	0.07		4.00	2.72	5.46	5.12			4.78
Frangi	2.40				2.50	4 70		0.04	0.40	4.00	2.40
Factory G.L.	3.42				3.59	1.76		2.24	6.40	1.38	3.13
Bergin Enterprise s LTD			1.07	0.45	0.36	0.20		0.12		0.50	0.45
Hospital Water Tank	31.09		57.20	51.38	38.95			78.58		49.81	51.17
Just Burgers Takeaway							0.65	0.64	0.87	0.54	0.67
Kia Orana								-	-	-	
ractory	5.32	1	1	1		1	I	1	1	1	5.32

KiiKii Motel	1 15	1 88	2 47	0.76	1 41	1 28	0.69	0.30	1 67	1 54	1.31
KiiKii							0.00	0.00			
Motel Lagoon	6.23	3.25	8.13	3.59	4.73	4.04	2.88	3.94	4.07	2.35	4.32
Lodges	44 75	0.50	10.07	F 70							44.47
Little	11.75	8.50	19.87	5.76							11.47
Polynesia n Motel	1 17		1.00	1 1 4	1.64	0.56	0.02	0.42	1 47	0.72	1.01
Little	1.17		1.00	1.14	1.04	0.56	0.92	0.42	1.47	0.73	1.01
Polynesia n Motel	6 49		10.22	2.07		1 4 9	0.02				6.06
Manihiki	0.40		19.55	2.07		1.40	0.92				0.00
Hotel			0.07			0.08					0.07
Manula Beach											
Hotel		13.50	23.40	12.83	10.14	10.08	11.04	6.61	20.67	2.73	12.33
Flats		0.50	1.07	0.93	0.41	1.08	0.35	0.15	0.40	0.38	0.58
Mauke Hostel	2 55	0.50	2 40	1 17	1 50	1 40	2.65	0.82	0.02	0.46	1.65
Moana	3.55	0.50	3.40	1.17	1.59	1.40	2.03	0.82	0.93	0.40	1.05
Sands Hotel	3 71	2 13	4.67	1.03	2 01	2 72	2 10	1 30	4 27	2 77	2 77
Muri	5.71	2.15	4.07	1.05	2.31	2.12	2.15	1.50	4.27	2.11	2.11
Beachcom ber Motel	37 19	65 75	58.60			9 44	59.46	61 73	70 40		51.80
Outrigger	07.10	00.10	00.00			0.11	00.10	01.10	70.10		01.00
Restaurant	0.30										0.30
Store		2.38	6.53	3.62	3.18	1.84	1.54	1.12	1.73	1.19	2.57
P J'S Bar & Cafe		6.25	11.80	4.97	2.41	7.52		6.67	11.93	8.27	7.48
Pacific				11.00	05.04	00.50	00.40	54.00	70.00	00.40	00.05
Parliament				41.09	85.04	88.52	82.12	54.09	73.20	38.40	00.25
House	0.86			0.28	0.32	0.36		0.33			0.43
Grove											
Lodges	0.75	0.38	1.93	0.52	0.55	0.24	1.42	0.45			0.78
Grove											
Lodges Portofino	2.57	2.25	4.60	1.93	1.82	0.48					2.28
Restaurant	7.59		3.67		9.14	7.52	1.69	1.60	3.27	3.62	4.76
Puaikura Reef											
Lodges	4.90	2.38	6.40	3.00		3.16	3.77	1.36	4.13		3.64
Puaikura Reef											
Lodges	0.01		0.33	0.45	5.14	0.16	0.12	0.42	0.20	2.73	1.06
Pukapuka Hostel	0.09	1.38	1.60	0.55	0.68	0.80	1.85	1.03	1.27	0.96	1.02
R.S.A.	6.61		12.40	0 50	7 1 4	6 33		2.00	E 47	2.21	6.61
Rarotonga	0.01		13.40	0.52	7.14	0.32		3.09	5.47	2.31	0.01
Breweries		14 38	39.47	22 17	13.45	14.96	12 35	12 18	13.47	7 12	16.62
Rarotonga		11.00	00.11		10.10	11.00	12.00	12.10	10.11	7.12	10.02
Golf Club			16.60		5.82	6.36		3.39			8.04
n Resort											
Hotel Rarotonga							135.23	126.06	155.67	37.23	113.55
n Sunset											
wotel Raymond	9.32		11.27	1.90					0.40		5.72
Pirangi		40.55	40.05		0.05			F 00	40 55		0.54
Rose Flats	5.50 0.65	10.50 26.75	13.93 41.93	4.79 23.45	8.95 0.55	5.16	3.69	5.33 4.52	10.53 7.93	4.00	8.51 11.86

Rose Flats	1.84	10.00	19.87	5.17	4.59	21.32	13.65	170.91	20.87	4.35	27.26
Sailing											
Club	4.13										4.13
Sails Restaurant			2.02	0.24							1 50
Snowbird			2.95	0.24							1.59
Laundry											
(Arorangi)	21.78		2.80		29.05			3.76			14.35
Snowbird											
Laundry											
(Avarua)	1.82		2.67	1.83	2.05	2.24	1.77	1.82	3.93		2.27
Sokala Villas		2.62	7 20	1 20	4 77	2.02	2 10	2.02	F 40	2.46	2 00
Squash		2.03	7.20	4.30	4.77	2.92	3.19	2.03	5.40	2.40	3.09
Centre	0.34	0.88	1.53	1.00	0.36	1.00		1.18	2.13	0.50	0.99
Sunrise											
Beach											
Motel	3.17	2.50	7.20	0.97	1.14	1.48	1.04	0.79	1.60	0.50	2.04
T - Shirt			0.00	0.4.4	0.00	0.00	0.05	0.45	0.00	0.40	0.47
Factory			0.20	0.14	0.09	0.08	0.35	0.15	0.20	0.12	0.17
Tamure Resort											
Hotel	3.00										3.00
Tepuka											
Pump											
Station		18.88				28.32		99.21	206.27	158.73	102.28
Tereora											
Pump Station		25.00	84 53	46 45	55 41						52 85
Trader		20.00	01.00	10.10	00.11						02.00
Jacks	10.11	3.38	4.07								5.85
Tumunu											
Bar &											
Rest.	20.50		21.20	1.59				9.15			13.11
rupapa Centre	0.76	2 88	5 60	9.03	5.00	6 80	377	3 64	1 73	3 88	4 31
Vaima	0.1.0	2.00	0.00	0.00	0.00	0.00	0	0.0 .		0.00	
Restaurant	0.80	0.75	1.87	0.69	0.73		0.58	0.42	0.73	0.15	0.75
Water											
Front											
narbour						8.76		10.36	22.60	16.50	14.56

Table 2: Metered Commercial	Demand in	Rarotonga
-----------------------------	-----------	-----------

	Dec93- Feb94	Oct96	Nov96	Dec96	Jan97	Mar97	Apr97	May97	Jun97	Aug97	Average
	(m3/d)	(m3/d)	(m3/d)	(m3/d)	(m3/d)	(m3/d)	(m3/d)	(m3/d)	(m3/d)	(m3/d)	(m3/d)
ANZ Bank											
Building		7.25	14.13	8.10	5.59	3.20	3.27	3.15	6.80	3.00	6.05
Audtorium Water Tank		2.25	6.00	2.90	2.14	3.44	9.15	1.88	3.53	1.62	3.66
CIDB Building	1.92										1.92
Cooks Conners											
Cafe	1.46	0.75	1.73	0.93	0.95	0.84	2.92	2.70	4.60	3.69	2.06
Cooks Conners Shopping Complex	2.76	2.00	5.20	2.59	2.41	2.88	0.92	0.94	1.80	1.08	2.26
Cultural Centre	4.13										4.13
Enuakura Petrol Station		0.63	1.07	0.62	0.91	0.68	0.69	1.06	0.33		0.75
Flame Tree Restaurant	7.23	8.88	0.07		4.00	2.72	5.46	5.12			4.78
Enterprises LTD			1.07	0.45	0.36	0.20		0.12		0.50	0.45
Just Burgers Takeaways							0.65	0.64	0.87	0.54	0.67
Outrigger Restaurant	0.30										0.30
P & M Store		2.38	6.53	3.62	3.18	1.84	1.54	1.12	1.73	1.19	2.57
P J'S Bar & Cafe		6.25	11.80	4.97	2.41	7.52		6.67	11.93	8.27	7.48
Portofino											
Restaurant	7.59		3.67		9.14	7.52	1.69	1.60	3.27	3.62	4.76
R.S.A. Club	6.61		13.40	8.52	7.14	6.32		3.09	5.47	2.31	6.61
Club			16.60		5.82	6.36		3.39			8.04
Raymond Pirangi Store	5.50	10.50	13.93	4.79	8.95			5.33	10.53		8.51
Sailing Club	4.13										4.13
Salls			2.02	0.24							1 50
Squash Centre	0.34	0.88	2.93	1.00	0.36	1.00		1 18	2 13	0.50	0.99
T - Shirt	0.04	0.00	1.00	1.00	0.00	1.00	<u> </u>	1.10	2.10	0.00	0.00
Factory			0.20	0.14	0.09	0.08	0.35	0.15	0.20	0.12	0.17
Trader Jacks	10.11	3.38	4.07								5.85
Tumunu Bar &											
Rest.	20.50	0.00	21.20	1.59		0.55	0 ==	9.15	4 = 2	0.00	13.11
Tupapa Centre Vaima	0.76	2.88	5.60	9.03	5.00	6.80	3.77	3.64	1.73	3.88	4.31
Restaurant	0.80	0.75	1.87	0.69	0.73		0.58	0.42	0.73	0.15	0.75
Average Commercial						I					<u> </u>
Use											3.84
Average											
Restauraunt Use											4.13
Average Store Use											4.44

	Dec93- Feb94 (m3/d)	Oct96 (m3/d)	Nov96 (m3/d)	Dec96 (m3/d)	Jan97 (m3/d)	Mar97 (m3/d)	Apr97 (m3/d)	May97 (m3/d)	Jun97 (m3/d)	Aug97 (m3/s)	Average (m3/s)
Airport Authority						15.88		16.76	17.73	45.46	23.96
B & M Heather LTD		<u> </u>	<u> </u>	0.69	0.59	0.48	0.42	0.30	0.47	0.31	0.47
B & M Heather LTD		4.88	16.53								10.70
Blue Pacific Laundry LTD	19.05	0.63									9.84
Concrete Structures LTD		0.50	2.67	2.76	1.09						1.75
Island Bottlers LTD	1.51	70.75	33.40	15.03	16.23	14.76		12.45		9.19	21.67
Frangi Factory	3.42				3.59	1.76		2.24	6.40	1.38	3.13
Kia Orana Factory	5.32										5.32
Rarotonga Breweries LTD		14.38	39.47	22.17	13.45	14.96	12.35	12.18	13.47	7.12	16.62
Snowbird Laundry (Arorangi)	21.78		2.80		29.05			3.76			14.35
Snowbird Laundry (Avarua)	1.82		2.67	1.83	2.05	2.24	1.77	1.82	3.93		2.27
Water Front Harbour						8.76		10.36	22.60	16.50	14.56
Average Industrial Use											10.38

Table 3: Metered Industrial Demand in Rarotonga

	Dec93- Feb94 (m3/d)	Oct96 (m3/d)	Nov96 (m3/d)	Dec96 (m3/d)	Jan97 (m3/d)	Mar97 (m3/d)	Apr97 (m3/d)	May97 (m3/d)	Jun97 (m3/d)	Aug97 (m3/d)	Average (m3/d)
Hospital											
Water Tank	31.09		57.20	51.38	38.95			78.58		49.81	51.17
Parliament											
House	0.86			0.28	0.32	0.36		0.33			0.43

Table 4: Metered Institutional Demand in Rarotonga

	Dec93-	OctOF	Nev06	Deelle	lon07	Mor07	Apr07	May07	lun07	Aug07	Average
	Feb94 (m3/d)	(m3/d)	NOV96 (m3/d)	Dec96 (m3/d)	Jan97 (m3/d)	(m3/d)	Apr97 (m3/d)	(m3/d)	Jun97 (m3/d)	Aug97 (m3/s)	Average (m3/s)
Are Renga Motel	20.40		25.80	16.97	18.18	13.72	18.73	20.76	36.07	22.96	21.51
Ariana											
Bungalows		9.38	31.87	18.00	15.73	17.00	16.42	21.67	53.20	24.85	23.12
Ati's Beach	2.20	2.42	1.00	4.00	2.00	4.40	6.40	4.00	C 00		4.05
Avana Marine	3.20	3.13	4.00	4.03	3.09	4.40	0.42	4.00	0.80		4.35
Condo's	3.51	1.50	4.93	2.10	5.23	1.44	3.15	1.82	5.07	4.54	3.33
KiiKii Motel	1.15	1.88	2.47	0.76	1.41	1.28	0.69	0.30	1.67	1.54	1.31
KiiKii Motel	6.23	3.25	8.13	3.59	4.73	4.04	2.88	3.94	4.07	2.35	4.32
Lagoon Lodges	44 75	0.50	40.07	5 70							44.47
Motel	11.75	8.50	19.87	5.76							11.47
Polynesian											
Motel	1.17		1.00	1.14	1.64	0.56	0.92	0.42	1.47	0.73	1.01
Little											
Polynesian											
Motel	6.48		19.33	2.07		1.48	0.92				6.06
Manihiki Hotel			0.07			0.08					0.07
Hotel		13 50	23 40	12 83	10 14	10.08	11 04	6.61	20.67	2 73	12 33
Mataora's Flats		0.50	1.07	0.93	0.41	1.08	0.35	0.15	0.40	0.38	0.58
Mauke Hostel	3.55	0.50	3.40	1.17	1.59	1.40	2.65	0.82	0.93	0.46	1.65
Moana Sands											
Hotel	3.71	2.13	4.67	1.03	2.91	2.72	2.19	1.30	4.27	2.77	2.77
Muri											
Motel	37 10	65 75	58.60			9.44	59.46	61 73	70.40		51.80
Pacific Resort	57.13	03.73	50.00	41.69	85.64	88.52	82.12	54.09	73.20	38.46	66.25
Plam Grove											
Lodges	0.75	0.38	1.93	0.52	0.55	0.24	1.42	0.45			0.78
Plam Grove											
Lodges Busikura Boof	2.57	2.25	4.60	1.93	1.82	0.48					2.28
Lodges	4.90	2.38	6.40	3.00		3.16	3.77	1.36	4.13		3.64
Puaikura Reef							-				
Lodges	0.01		0.33	0.45	5.14	0.16	0.12	0.42	0.20	2.73	1.06
Pukapuka		1.00	1.00	0.55	0.00		4.05	4.00	4.07		4.00
Parotongan	0.09	1.38	1.60	0.55	0.68	0.80	1.85	1.03	1.27	0.96	1.02
Resort Hotel							135.23	126.06	155.67	37.23	113.55
Rarotongan											
Sunset Motel	9.32		11.27	1.90					0.40		5.72
Rose Flats	0.65	26.75	41.93	23.45	0.55	5.16	3.69	4.52	7.93	4.00	11.86
Rose Flats	1.84	10.00	19.87	5.17	4.59	21.32	13.65	170.91	20.87	4.35	27.26
Suprise Beach		2.63	7.20	4.38	4.77	2.92	3.19	2.03	5.40	2.46	3.89
Motel	3.17	2.50	7.20	0.97	1.14	1.48	1.04	0.79	1.60	0.50	2.04
Tamure Resort											
Hotel	3.00										3.00
Average Hotel Use											13.86
Average Big											
Hotel Use (>5 m3/d)											31.90
Average Hostel Use											1.33
Average Little Hotel Use (<5m3/d)											2.18

Table 5: Metered Hotel Demand in Rarotonga
Table 6: Determination of Agricultural Demand

			Est.			Equivalent	Mean	% of			
		1	Plants per	Total Plant		crop type	Temp- T	daytime	Consumptive	Consumptive	Demand
Crops	Acreage	Area (m2)	Acre	Count	Kbc	for Kbc	(oC)	hours- p	Use (mm)	Volume (m3)	(m3/d)
Pawpaw	60	242820	800	48000	0.6	grapes	25	8.3	98	23747	779
Citrus	30	121410	430	12900	0.55	oranges	25	8.3	90	10884	357
Banana	20	80940	800	16000	0.85	corn	25	8.3	139	11214	368
Vegetable-leafy	10	40470	14500	145000	0.9	alfalfa	25	8.3	147	5937	195
Vegetable- fruits	20	80940	4800	96000	0.75	beets	25	8.3	122	9895	324
Vegetable-pulses	10	40470	14500	145000	0.7	beans	25	8.3	114	4618	151
Taro-dry	25	101175	7000	175000	0.75	potatoes	25	8.3	122	12368	406
Chilli	5	20235	4800	24000	0.7	tomatoes	25	8.3	114	2309	76
Total	180	728460							945	80972	2655

Using the Blaney-Criddle equation to determine water consumption by individual crops. U = 45.7 Kbc(T + 17.8)p/100

Comparative North American Kbc crop values were used.

Average Agricultural Demand from French records '92-'94 = 3.4 m3/plot*d Average of 2 locations 60 % Rarotonga households engage in agricultural activity 2569 Households on Rarotonga

1541.4 Households engaged in agriculture (# of plots)

5240.76 Agricultural demand (m3/d) 360 Counted agricultural plots from 1:25000 map of Rarotonga

Table 7: Total Demand in Rarotonga

	Number of					Known					
	Establishments			Typical	Typical	Metered		Known	Total	ADB	Alternate
	from Raro		Descriptio	Demand	Demand	Demand	Description of Known	Demand	Demand	Demands	Demands
Building Type	Yellow Pas (#)	Unit	n of Unit	(L/unit*d)	(m3/d)	(m3/#*d)	Demand Value	(m3/d)	(m3/d)	(m3/d)	(m3/d)
Domestic	2569	10558	people	220	2323	0.3		3167	3167	2403	2640
Small Hotels (< 5m3/d)	12	901	beds	190	171	2.18	Average for <5m3 hotels	26			
Larger Hotels	56	988	beds	200	198	31.9	Average for >5m3 hotels	1787			
Hotels	68							1813	1813	899	-
Restaurants	20	180	meals	35	126	4.13	Average restaurant demand	83			
Car & Bike Rental	10	30	vehicles	40	12		-				
Boutiques	4	3	employee	40	0.48	0.17	Based on t-shirt factory	0.7			
Car Sales	4					0.45	GL Bergin car sellers	1.8			
Car Service	16	10	vehicles	40	6.4						
Cinema	1	140	seats	10	1.4						
Clubs	6	50	member	250	75	6.09	Avg of Sailing and golf club	37			
Engraver	1					5.59	Avg of B&M construction Co	5.6			
Food Stores	34					5.54	Avg of P&M and Ray's Store	188			
Jewellery	4					0.2	Based on t-shirt factory	0.8			
Liquor	6					0.2	Based on t-shirt factory	1.2			
Music Shops	8					0.2	Based on t-shirt factory	1.6			
Gas Stations	16					0.75	Enuakura gas station	12			
Arts & Crafts	16					2.02	From 3 stores in ANZ building	32			
Bakeries	7					5.54	Avg of P&M and Ray's Store	39			
Banks	6	15	employee	55	4.95	1.92	Same as CIDB	12			
Bars	17	50	customer	8	6.8	4.31	Tupapa Centre	73			
Cultural Centre	1					4.13	auditorium/library/museum	4.1			
Salons	3					3	Estimated	9			
Clothing Stores	12					2.02	From 3 stores in ANZ building	24			
Total Commercial	192						9	544.1918	1066	602	-
Actual Commercial	376										
Airport	1	500	passenger	10	5	24.0	Airport	24.0			
Breweries	2	10	employee	55	1.1	16.6	Rarotoga brewery	33.2			
Textiles	4					0.5	Based on t-shirt factory	2			
Glass Works	2	5	employee	55	0.55	10.7	Higher B&M construction Co	21.4			
Ice Cream Maker	1					3.1	Frangi Frozen foods	3.1			
Laundry	3	15	machines	2000	90	8.8	Avg of Laundry	26.5			
Press	1	10	employee	55	0.55		Higher B&M construction Co				
Drink Factory	2	10	employee	55	1.1	13.5	Avg of Kia Orana & CI Bottlers	27.0			
Meat Supplier	1					3.1	Frangi Frozen foods	3.1			
Shipping	1					14.6	Waterfront	14.6			
Construction Co	8	15	employee	55	6.6	5.6	Avg of B&M	44.7			
Total Industrial	25							200.1	424	795	-
Actual Industrial	53					-					
Churches	24	7239.8	people	8	58						
University	1	252	students	40	10						
Gov't Offices	19	1200	employee	55	66	0.43	Parliament building	8.2			
Hospital	1	70	beds	650	46	51.2	Hospital tank	51.2			
Prison	1	20	inmates	450	9						
Schools	9	2793	students	60	168						
Total institutional	55							362	362	361	-
Estimated Agricultural									5241	3775	2655
Total Demand									12073	8835	8959

Actual Commercial and Industral premises from ADB report, based on te Aponga (Rarotonga Electricity Authority) billing records. Total are for the values in grey.

Table 8: Demand from Rarotonga's Intakes

	Average	Avg Demand			
	Demand	from Intake			
	from	according to			
	Intake	French			
Intakes	(m3/d)	(m3/d)	Elev (m)	Filtered	Comments
Turangi	2600	2074	69.1	У	best intake
Avana	2300	3400	78.4	n	
Avatiu	1650	1728	77.8	У	
Takuvaine	1650	2419	66.9	У	
Papua	2000	2160	46.8	n	
Taipara	2100	1100	47.5	У	
Ngatoe	1000		65	У	new 92
Tupapa	1000			У	new 93
Totokoitu	1000	1555	55.1	n	
Matavera	1900			У	new 94
Rutaki	400	432	48.5	У	
Muriavai	700	864	58.4	n	
Total	18300	19632			

Appendix C: Descretized Demand Data for Turangi

		Number of	Demand	Total	Demand	
Junction	User	Users	(m3/d)	Demand (L/s) (L/s)		Description of Demand Value
J-189	Houses	19		0.27		
	UC	1		0.01		Using domestic demand
	total demand at junction				0.29	
J-190	Parliament		0.43	0.005	0.15	Metered location
	Frangi		3.13	0.04		Metered location
	Timber House		4.44	0.05		Same as store demand
	Cooks Corner Bus Services		1.2	0.01		Same as petrol station + G.L. Car Sellers
	Houses	19		0.27		
	Agricultural			0.15		
	total demand at junction				0.53	
	demand used in the model				0.20	
I-191	Airport		23.96	0.28		Metered location
	Mainline Office		0.55	0.01		Using typical office demand assuming 10 workers
	Blue Pacific Laundry		9.84	0.12		Metered location
	Triad		4,44	0.05		Same as store demand
	Catholic Cemetary			0.04		Same as agricultual demand
	Resene Paints		1.75	0.02		Same as Concrete Structures Ltd
	Clinic		2.6	0.03		typical hospital demand assuming 4 beds
	CIDB		1.92	0.02		Metered location
	Motor Centre		0.75	0.01		Same as Enuakura Petrol Station
	Manu Manea		0.17	0.002		Same as t-shirt factory
	Tyre Centre		0.75	0.01		Same as Enuakura Petrol Station
	Airfreight Int		0.55	0.01		Same as wearhouse demand
	Cook Is Steel Ind		10.7	0.12		Same as B&M Ltd Construction
	Houses	50		0.71		-wnere make blocks
	VE	2	4.44	0.10		Average store demand
	Agricultural	1		0.20		
	total			0.20	1.85	
I-192	Palm Hardware			0.003		Using typical shopping centre assuming 6 workers
I-210	Mobil		0.75	0.01		Same as Enuakura Petrol Station
	Fletcher and John Short			0.01		Typical office demand assuming 10 employees
	House of Ariki		0.43	0.005		Same as parliament
	Printing Office		0.55	0.01		From typical demands assuming 10 employees
	Taro Swamp	1		0.04		Same as agricultual demand
	Avatiu Rugby Field			0.04		Same as agricultual demand
	LDS Church		2.41	0.03		typical demands assuming 302 church/M. house attendees
	Cemetary			0.04		Same as agricultual demand
	Club House		4.13	0.05		Average bar & restaurant demand
	Tere's Bar		4.13	0.05		Average bar & restaurant demand
	Meeting House		2.41	0.03		typical demands assuming 302 church/M. house attendees
	Bargan Contro		4.44	0.01		Same as wearhouse demand
	Stores	2	4.44	0.05		Average store demand
	Houses	- 35		0.50		riterage store demand
	VF	3		0.00		
	UC	1		0.01		Using domestic demand
	VU	1		0		
	Agricultural			0.17		
	total				1.15	50% to each junction
J-212	Warehouse		0.55	0.01		typical industrial building demand assuming 10 employees
J-47	Workshop		0.55	0.01		typical industrial building demand assuming 10 employees
	Coco Photos			0.002		Typical office demand assuming 3 workers
	Rental Cars		0.45	0.01		same as GL Bergin car sellers
	Raro Safari Tour Guides		0.17	0.01		I ypical office demand assuming 10 employees
	Maating House		0.17	0.002		Same as t-shirt factory
			2.41	0.03		Typical demands assuming 302 church/w. house allendees
	Houses	10	0.44	0.14		rypical once demand assuming o workers
	total	10		0.14	0.20	50% to each junction
I-193	Poly Rakei		0.17	0.002		Same as t-shirt factory
	Te Mato Tupuranga		1.1	0.01		typical office demand, assuming 20 workers
	South Seas			0.004		Typical department store demand assuming 8 workers
	Furniture Centre		4.44	0.05		Same as store demand
	Houses	16		0.23		
	UC	1		0.01		Using domestic demand
	total				0.31	
I-194	Catholic Church		2.41	0.03		typical demands assuming 302 church/M. house attendees
Node 10b	St. Joseph Hall		2.41	0.03		typical demands assuming 302 church/M. house attendees
	Budget Rental		0.45	0.01		same as GL Bergin car sellers
	Konnies Bar/Rest		4.13	0.05		Average bar & restaurant demand
	Goldmine Voppials		0.17	0.002		Same as t-shift factory
	Mana Court		0.47	0.005		spical department store demand assuming 12 workers
	Houses	-	0.17	0.002		ourise as training the topy
	total	/		0.10	0 22	75% to Node 10b. 25% to J-194
Node 10a	Island Craft		0.17	0.002	0.22	Same as t-shirt factory
Node 10ai	Westpac Bank		1.92	0.02		Same as CIDB
	Foodland		4.44	0.05		Same as average store
	Mana's Café		2.06	0.02		Same as Cook's Corner Café
	CIDB Building		1.92	0.02		Metered location
	Police Dept		2.37	0.03		same as CIDB Building and GL Bergin car sellers
	Rental Cars		0.45	0.01		same as GL Bergin car sellers
	Petrol Station		0.75	0.01		Same as Enuakura Petrol Station
	Cooks Corner		4.32	0.05		Cook's Corner + Cook's Corner Café
	Offsbank		1.92	0.02		same as CIDB Building
	CITC		6.48	0.08		typical department store demand, assuming 2 toilet rooms, 62 workers
	Houses	5		0.07		
	total				0.38	75% to Node 10ai, 25% to Node 10a
I-81	Matina Travels		0.66	0.01		Typical office demand assuming 12 workers
Node 9i	Tourist Authority			0.01		Typical office demand assuming 12 workers
Node 9	Banana Court		4.13	0.05		Average bar & restaurant demand
	Administration Block		4.125	0.05		typical office demand assuming 75 workers
	Philatelic Small Rusiness			0.01		typical office demand assuming 10 workers
	Electrical		4.44	0.05		Same as B&M I to Construction-lower value
	LIGUIIUBI		0.47	0.01		Game as Daw Lta. Construction-IOWER Value

Type of User		
Demand	Value	Unit
Commercial	0.044	L/est*s
Domestic	0.014	L/house*s
Hotel	0.16	L/hotel *s
Industrial	0.12	L/est*s
Institutional	0.18	L/est*s
Agricultural	0.039	L/plot*s
Turangi Clinics	2.6	m3/clinic*d
Turangi Churches	3.02	m3/church*d
Warehouse	0.55	m3/warehouse*d
Bar & Restaurant	4.13	m3/est*d
Store	4.44	m3/est*d

0.000012 L/d into L/s 0.011574 m3/d into L/s 0.001 L/d into m3/d Conversion Conversion Conversion

Total number of Junctions in Turangi Zone = 88 Average Demand from Turangi Intake = 2600 m3/d

VU - Vacant, Unfit for living VF - Vacant, Fit for living UC - Under Construction

						1
	Waterfront Harbour		14.56	0.17		Metered demand
	Stores	1	4.44	0.05		Average store demand
	Houses	2		0.03		
	total				0.42	40% to Node 9 amd J-81, 20% to Node 9i
J-223	Brewery		16.62	0.19		Assuming Rarotonga Brewereies- metered
	Prestige		1.75	0.02		Same as Concrete Structures Ltd.
	Cook Is News			0.01		typical office demand assuming 15 workers
	Cook Is Sports			0.01		typical office demand assuming 15 workers
	Central Motel		13.86	0.16		same as average hotel demand
	Houses	17		0.24		
	total				0.63	
J-99	Clinic		2.6	0.03		typical hospital demand assuming 4beds
Node 3	Meeting House		2.41	0.03		typical demands assuming 302 church/M. house attendees
	Stores	2	4.44	0.10		
	Houses	39	-	0.56		
	total				0.72	50% to each Junction
Node 4	Administration Block			0.05		typical office demand assuming 80 workers
Node 4i	Theological College			0.04		typical school demand assuming 60 students
	USP		10.08	0.12		From typical demand assuming 252 students
	Aitutaki Hostel		1.33	0.02		average hostel
	Avarua School			0.10		typical school demand assuming 150 students
	Houses	22		0.31		
	total				0.64	50% to each Junction
J-213	Are Taunga		0.17	0.002		Same as t-shirt factory
	Marine Resources			0.01		typical office demand assuming 15 workers
	Empire Theater		1.4	0.02		From typical theater demand assuming 140 seats
	Raro Records		0.17	0.002		Same as t-shirt factory
	Vanwil Agencies		4.44	0.05		typical office demand assuming 10 workers
	Stores	1	4.44	0.05		Average store demand
	Houses	3		0.04		
	total				0.18	
J-84	Para O Tane Palace			0.03		Same as domestic domand
J-215	Library		1.38	0.02		one third cultural centre value
J-214	CICC Church		2 41	0.03		typical demands assuming 302 church/M house attendees
	Sinai Hall		2.41	0.03		typical demands assuming 302 church/M house attendees
	Print Office		0.55	0.01		From typical demands assuming 10 employees
	Atiu Hostel		1 33	0.02		average hostel
	Houses	10	1.00	0.14		avorago nostor
	MI	1		0.14		
	total			0	0.26	33% to each junction
1-86	Mani Hostel		1 33	0.02	0.20	average hostel
0.00	Mauke Hostel		1.65	0.02		Metered location
	Mitiaro Hostel		1.05	0.02		average bostol
	Houses	14	1.55	0.02		average noster
	Storee	14	4.44	0.20		Average store demand
	total		4.44	0.03	0.30	Average store demand
1-87	Shed		0.55	0.01	0.00	Same as wearbouse demand
0 0.	Tupana Contro		4 21	0.05		Matered location
	Mangaia Hostel		1 33	0.02		average hostel
	Houses	4	1.00	0.06		avorago nostor
	total			0.00	0.13	
J-98	Maraerenga Clinic		26	0.03		typical hospital demand assuming 4beds
Node 5	Pai Taro		0.55	0.03		Same as weathouse demand
110000	Houses	4	0.00	0.06		
	total	4		0.00	0.09	50% to each junction
1.216	Raradica Ion		12.96	0.16	0.03	Average batel demand
Node R	Monting House		2.41	0.02		tunical domande accuming 202 church/M house attendees
Nodo Ri	Restaurant		4.12	0.05		Average restaurant demand
11000001	Storee	4	4.10	0.00		Average store demand
	Houses	36		0.51		riterage store demand
	total	00		0.01	96.0	45% to 1-216 and Node 8, 10% to Node 8i
J-217	Cultural Centre-Library		4.13	0.05		Metered location
0 217	Museum Auditorium		4.10	0.00		inclored location
	NZ Maori Hostel		1 33	0.02		average hostel
	Pukapu Hostel		1.02	0.01		Metered location
	Penr. Hostel		1.33	0.02		average bostel
	Tupapa Rugby Field			0.04		Same as agricultual demand
	Tupapa Netball Court			0.04		Same as agricultual demand
	Houses	7		0.10		
	VE	. 1		0.10		
	total			-	0.27	
I-218	Meeting House		2.41	0.03	0.27	typical demands assuming 302 church/M house attendees
J-219	Dental Clinic		26	0.03		typical hospital demand assuming 4beds
1	Out Patient		2.6	0.03		typical hospital demand assuming 4beds
I	Stores	1	4.44	0.05		Average store demand
I	Houses	24		0.34		
	VE	1		0		
	total				0.48	50% to each Junction
J-89	Houses	24		0.34		
	Stores	1	4 44	0.05		Average store demand
	VF	1		0		
	Agriculural			0.16		
	total				0.55	
Node 6	Old t-shirt Eactory		0.17	0.002		Same as t-shirt factory
Node 6i	Aramoana Flats		11.86	0.14		Same as Rose Flats, the sans pool connection
	Houses	13		0 19		
I	Agricultural			0.09		
I	total				0.41	50% to each Junction
J-100	Avarua Bakerv		5.54	0.06	2.41	Same as for food stores
ľ	Triad Storage		0.55	0.01		Same as wearhouse demand
I	Houses	11	2.00	0.16		
I	VF	1		0.10 N		
				0.30		
	Agricultural			0.00	0.52	
	Agricultural				0.00	
.l-141	Agricultural total		0.67	0.01		Metered location
J-141 Node 7	Agricultural total Just Burgers Houses	10	0.67	0.01		Metered location
J-141 Node 7	Agricultural total Just Burgers Houses Stores	10 2	0.67	0.01 0.14 0.10		Metered location
J-141 Node 7	Agricultural total Just Burgers Houses Stores Vul	10 2 2	0.67	0.01 0.14 0.10		Metered location Average store demand
J-141 Node 7	Agricultural total Just Burgers Houses Stores VU total	10 2 2	0.67 4.44	0.01 0.14 0.10 0	0.25	Metered location Average store demand 90% to J-141 10% to Node 7
J-141 Node 7	Agricultural total Just Burgers Houses Stores VU total Clinic	10 2 2	0.67 4.44 26	0.01 0.14 0.10 0	0.25	Metered location Average store demand 90% to J-141, 10% to Node 7 Durical hospital demand assuming 4he4*
J-141 Node 7 J-106	Agricultural total Just Eurgers Houses Stores VU total Clinic Clinic Office	10 2 2	0.67 4.44 2.6	0.01 0.14 0.10 0 0.03 0.01	0.25	Metered location Average store demand 90% to J-141, 10% to Node 7 Typical Nospital demand assuming 4beds typical force demand assuming 20 workers
J-141 Node 7 J-106	Agricultural total Just Burgers Houses Stores VU total Clinic Internal Affairs Office Houses	10 2 2 17	0.67 4.44 2.6	0.01 0.14 0.10 0 0.03 0.01 0.24	0.25	Metered location Average store demand 90% to J-141, 10% to Node 7 typical hospital demand assuming 4beds typical office demand assuming 20 workers
J-141 Node 7 J-106	Agricultural total Just Burgers Houses Stores VU total Clinic Internal Affairs Office Houses Stores	10 2 2 17 1	0.67 4.44 2.6 4.44	0.01 0.14 0.10 0 0.03 0.01 0.24 0.05	0.25	Metered location Average store demand 90% to J-141, 10% to Node 7 typical hospital demand assuming 4beds typical office demand assuming 20 workers Average store demand

I	VF	1		0		
	total				0.34	
J-92	Stores Houses	2	4.44	0.10		Average store demand
	total				0.42	
J-131	Houses	11		0.16		
J-130	UC	1		0.01		Using domestic demand
	total				0.17	90% to J-131, 10% to J-130
J-94	Houses	8		0.11		
	Agricultural			0.03	0.14	
J-95	APOS Church		2.41	0.03		typical demands assuming 302 church/M. house attendees
J-101	Fishing Club		4.13	0.05		Same as sailing club
	Houses	28		0.40		I Ising domestic demand
	Agricultural	2		0.23		Using domestic demand
	total				0.73	90% to J-101, 10% to J-95
J-139	Houses	15		0.21		
J-140	total			0.37	0.59	90% to J-140, 10% to J-139
J-93	Club Raro Resort		31.9	0.37		Same as big hotel demand
	Kiikii Motel		5.63	0.07		Metered location
	Houses	18	13.80	0.16		Same as average notel demand
	Stores	1	4.44	0.05		Average store demand
	VF	1		0		
.1-96	Clinic		26	0.03	0.90	typical hospital demand assuming 4beds
J-122	Houses	34	2.0	0.49		ryplaar noopilal domand doodining 40000
	VF	2		0		
	Agricultural			0.43	0.05	00% to 1.05 10% to 1.122
J-102	Houses	21		0.30	0.95	30% 103-30, 10% 10 J-122
	VF	1		0		
	Agricultural			0.24		
J-103	total Houses	6		0.09	0.54	
0 100	Agricultural	0		0.43		
	total				0.52	
J-121	Houses	14		0.20		
	total			0.50	0.76	
J-90	Houses	4		0.06		
J-120	Clinic		2.6	0.03		typical hospital demand assuming 4beds
	Agricultural			0.20	0.29	90% to J-90. 10% to J-120
J-119	Houses	27		0.39		
	Stores	1	4.44	0.05		Average store demand
	Agricultural			0.05	0.49	
J-104	Houses	8		0.11	0.43	
	UC	1		0.01		Using domestic demand
	total				0.13	
J-138 J-137	Agricultural	22		0.31		
	total				0.59	90% to J-138, 10% to J-137
J-118	Peasat			0.002		Typical office demand assuming 3 employees
	Houses	39	4 44	0.56		Average store demand
	Agricultural			0.26		
	total				0.92	
J-129	Matavera Primary School Houses	14		0.10		typical school demand assuming 140 students
3-120	Agricultural	14		0.39		
	total				0.69	90% to J-129, 10% to J-126
J-105	Houses	41		0.59		
J-110	total			0.35	0.94	50% to each Junction
J-117	Houses	8		0.11		
	VU	1		0		
1	Agricultural total			0.02	0.11	
J-114	Packing Shed		0.55	0.01		Same as wearhouse demand
1	Meeting House		2.41	0.03		typical demands assuming 302 church/M. house attendees
	Stores	2	4.44	0.10		Average store demand
	total	15		0.21	0.35	
J-115	Houses	10		0.14		
	VF	1		0		
	Agricultural			0.28	0.42	
J-109	Houses	9		0.13		
	VF	1		0		
1	Agricultural			0.28	0.40	
J-108	Houses	7		0.10	0.40	
L	total				0.10	
J-111	Houses	4		0.06		Ileina domestic domand
J-133	total	2		0.03	0.09	90% to J-133, 10% to J-111
J-112	Houses	6		0.09		
	total				0.09	
J-116	Houses	6		0.09		
	total			0.20	0.20	
J-80	Catholic Church		2.41	0.03		typical demands assuming 302 church/M. house attendees
J-113	SDA Church		2.41	0.03		typical demands assuming 302 church/M. house attendees
1	Sunday School Hall		2.0	0.03		typical demands assuming 302 church/M. house attendees
1	Houses	14		0.20		
1	VU	1		0	0.71	00% to 1.80, 10% to 1.112
L	total				0.31	30% to J-80, 10% to J-113

J-135	CICC Church		2.41	0.03	typical demands assuming 302 church/M. house atten	dees
J-136	Houses	24		0.34		
	VF	3		0		
	Agricultural			0.31		
	total				0.69 90% to J-135, 10% to J-136	
J-125	Clinic		2.6	0.03	typical hospital demand assuming 4beds	
J-107	Houses	48		0.68		
	Stores	1	4.44	0.05	Average store demand	
	VF	2		0		
	total				0.77 90% to J-125, 10% to J-107	
J-124	Sunrise Beach Motel		2.04	0.02	Metered location	
	Houses	25		0.36		
	Stores	2	4.44	0.10	Average store demand	
	VF	3		0		
	VU	1		0		
	UC	1		0.01	Using domestic demand	
	Agricultural			0.08		
	total				0.58	
J-132	Houses	13		0.19		
J-123	UC	1		0.01	Using domestic demand	
J-134	Agricultural			0.47		
	total				0.67 33% to each Junction	
J-128	Houses	15		0.21		
	UC	1		0.01	Using domestic demand	
	Agricultural			0.28		
	total				0.50	
J-127	Vaka Village			0.02	Typical demand assuming 1 public toilets	
J-78	Sunday School Hall		2.41	0.03	typical demands assuming 302 church/M. house atten	dees
	CICC Church		2.41	0.03	typical demands assuming 302 church/M. house atten	dees
	Are Vaka			0.02	Typical demand assuming 1 public toilets	
	Houses	31		0.44		
	VF	5		0		
	UC	1		0.01	Using domestic demand	
	total				0.56 50% to each Junction	
Total Tur	angi demand			27.22	27.22 L/s	

I

Total Turangi demand Total Turangi demand Measured Flow from Turangi Intake Measured Flow from Turangi Intake

27.22 2351 m3/d 2600 m3/d 30.1 L/s

		Plots		
	Area of	Counted		
hunat's	MapInfo	1:25000	Total Area	Agricultural
Junction J-190	1607	Мар	(m2)	Demand (L/s)
0 100	3449			
	1431		6407	0.454
J-191	803		6487	0.151
	749			
	4332			
	1119			
	1473		8476	0.197
J-210	2785			
	982			
	521			
	1046			
			6032	0.140
J-192	1491		1/01	0.035
J-89		4	1491	0.035
			6768	0.157
Node6	1970			
	1859		3829	0.089
J-100	1980			
	1558			
	1453			
	1430 3281			
	2441			
	784		40007	0.001
J-94	1102		12927	0.301
	1102		1102	0.026
J-101	3798			
J-95	934	2		
		3	9808	0.228
J-139	2161			
J-140	6738			
	2045	2		
		3	16020	0.373
J-96	4107		-	
J-122	2220			
	2085			
	1057			
	2265			
	1023			
	1288			
	2822		18546	0.431
J-102	3653			
		4	40.00	0.010
L-121	1014		10421	0.242
J- ∠	1869			
	1962			
	2670			
	1460			
	3317 2212			
	8706			
	682			
L102		4.4	23892	0.556
J-103 J-104		11	<u>186</u> 12	0.433
J-90	851		-	
J-120	509			
	1345 1498			
	4503			
			8706	0.202
J-119	2124		2124	0.049
J-118	1052		2124	0.049
	1655			
	1439			

	1581			
	1358			
	2207			
	585			
	1173			
			11050	0.257
J-137		7		
J-138			11844	0.275
J-105		9		
			15228	0.354
J-129	6822			
J-126		6		
			16974	0.395
J-117	805			
			805	0.019
J-115		7		
			11844	0.275
J-110		5		
			8460	0.197
J-109		2		
			3384	0.079
J-116		5		
			8460	0.197
J-135		8		
J-136			13536	0.315
J-134		12		
J-132			20304	0.472
J-123				
J-124	1425			
	2037			
			3462	0.081
J-128		7		
			11844	0.275
T - 1 - 1			000400	

Approximation Approximation 1 3.444 1 3.444 1 3.444 1 3.444 1 3.444 1 3.444 1 3.444 1 3.444 1 3.444 1 3.444 1 1.445 1 1.445 1 1.445 1 1.445 1 1.445 1 1.445 1 1.445 1 1.445 1 1.445 1 1.517 1 1.517 1 1.517 1 1.517 1 1.517 1 1.517 1 1.517 1 1.517 1 1.517 1 1.517 1 1.517 1 1.517 1 1.517	Table 3: Determinat	ion of Total	Area of Agricultural Plots in Rarotonga	
1 1000 2 1000 1 1000	Agricultural Plot	Area (m2)		
1.444 Martin Agriculturi Robin Agriculturi R	1	1607		
1 7.00 Creating and public pu	2	3449	Median Agricultural Plot Area -	1602 m2
8 1785 Table Spine, Agencular Agence 9433 7 1787 Additional Agence 1787 7 1787 Additional Agence 1787 8 1181 Additional Agence 1787 8 1181 Ame of Agronulural Pote in Randorog as determined by Dept of Agricultura Agence 2 11 100 Percent Difference 2 12 101 Percent Difference 2 13 101 Percent Difference 2 14 101 101 Percent Difference 2 15 101 101 101 101 16 101 101 101 101 17 100 101 101 101 18 101 101 101 101 19 101 101 101 101 101 100 101 101 101 102 1010 101 101 101 103 1010 101 101 101 103 1010 101 101 101 104 1020 101 101 101 105 1010 101 101 101	4	749	Average Agricultural Plot Area =	2248 m2
0 15/70 Additional Agricultural Price Converter from mage of Paratrongs = 198272 m2 10 4532 Tead Agricultural Price in Ranotrongs at Othermined Dipt of Agricultural Price 728407 %2 11 4. Ass of Agricultural Price in Ranotrongs at Othermined Dipt of Agricultural Price 728407 %2 12 10 11 11 11 13 12 12 12 14 13 14 14 14 15 14 14 14 14 14 14 14 14 14 14 15 15 15 15 15 15 15 15 15 15 16 16 16 16 16 17 13.58 16 16 16 18 16 16 16 16 19 155 16 17 15 19 16 16 16 16 19 16 16 16 16 10 16 16 16 16	5	1795	Total MapInfo Agricultural Area =	548432
7 1782 Additional Agricultural Pres in Ratoleroga as determined by Dept of Agriculture = 728400 % 1 440 Agricultural Pres in Ratoleroga as determined by Dept of Agriculture = 2 1 440 Agricultural Pres in Ratoleroga as determined by Dept of Agriculture = 2 1 440 Agricultural Pres in Ratoleroga as determined by Dept of Agriculture = 2 1 440 Agricultural Pres in Ratoleroga as determined by Dept of Agriculture = 2 1 440 Agricultural Pres in Ratoleroga as determined by Dept of Agriculture = 2 1 440 Agricultural Pres in Ratoleroga as determined by Dept of Agriculture = 2 1 440 Agricultural Pres in Ratoleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patroleroga as determined by Dept of Agricultural Pres in Patrolerof Patroleroga as determined by Dept of Agri	6	15476	Additional Agricultural Plots Counted from map of Rarotonga =	116 m2
8 432 Ana of Agricultural Picts in Ranctoraga as determination 2728400 %. 110 Ana of Agricultural Picts in Ranctoraga as determination 2728400 %. 2 12 521 521 13 110 110 1473 111 111 1473 111 111 1474 111 111 1474 111 111 1475 111 111 1475 111 111 1476 111 111 1476 111 111 1476 111 111 1476 111 111 1477 1110 111 1478 1111 1111 1479 1111 1111 1481 1111 1111 1481 1111 1111 1481 1111 1111 1481 1111 1111 1481 1111 1111 1481 1111 1111	7	1782	Additional Agricultural Area =	196272 m2
1110 Area of Apricultural Plots in Rectorings as determined by Deck of Apriculture = 2 12 321 13 Person Defension = 2 143 Person Defension = 2 153 1111 154 1111 155 1111 154 1111 155 1111 155 1111 155 1111 155 1111 155 1111	8	4332	Total Agricultural Area =	744704 m2
10 1473 Percent Difference = 2 12 621 13 111 14 111 15 111 16 111 17 133 18 611 19 030 19 030 19 030 11 631 12 534 13 632 14 634 15 1060 16 635 17 138 18 636 19 638 19 638 10 637 11 136 10 137 138 1341 1491 1341 141 1341 142 1407 143 1344 144 1365 145 1346 146 1348 147 1348 148 1407 149 1417 144 1407 145 1416 146 1426 147 1438 148 1426 1498 1426 <th>9</th> <th>1119</th> <th>Area of Agricultural Plots in Rarotonga as determined by Dept of Agriculture =</th> <th>728460 %</th>	9	1119	Area of Agricultural Plots in Rarotonga as determined by Dept of Agriculture =	728460 %
1 924 12 2745 13 2745 14 6171 15 6171 16 6171 17 1336 18 633 20 939 21 1030 22 1030 23 924 24 636 25 1046 26 1491 27 1032 28 322 29 322 20 326 21 1041 22 1042 23 322 30 361 31 1541 32 1541 33 1543 34 1541 35 1551 36 1551 37 144 38 1551 39 1102 30 1551 3153	10	1473	Percent Difference =	2
12 321 13 517 14 517 15 517 17 133 17 133 18 517 19 633 21 224 22 924 23 924 24 638 25 1046 26 1047 27 539 28 322 29 322 29 322 29 324 20 1441 21 1545 22 322 23 321 24 1076 25 1544 26 1657 27 1364 26 157 26 1657 26 1657 27 162 26 1657 27 162 26 1657	11	982		
1 0 0 1 0 00 1 0 00 2 100 00 2 100 00 2 100 00 2 100 00 2 100 00 2 100 00 2 100 00 2 100 00 2 100 00 2 100 00 2 100 00 3 104 00 3 104 00 3 105 00 3 105 00 3 105 00 3 105 00 3 105 00 3 105 00 3 105 00 3 105 00 3 105 00 4 205 00 4 205 00 5 105 00 <th>12</th> <th>2785</th> <th></th> <th></th>	12	2785		
1 133 17 133 18 631 19 633 20 939 21 524 22 924 23 924 24 638 25 1040 26 1041 27 538 28 124 29 322 30 1076 31 1076 32 1940 33 1948 34 1977 35 1980 36 1941 37 1950 38 1977 39 1957 30 1934 41 2221 42 2461 43 1977 44 2058 45 1947 46 1079 47 4107 48 2626 49 1935 52 1014 53 1935 <	13	5117		
	15	616		
	16	891		
	17	1336		
19 885 21 552 22 926 23 924 24 986 25 1446 26 1447 27 588 28 932 29 932 30 381 31 1076 33 1544 34 1544 35 1970 36 1859 37 1890 38 1644 39 1102 073 1890 39 102 073 1890 39 102 41 2161 42 107 43 2220 44 2161 45 1667 46 1667 47 1022 48 2282 49 2282 51 365 52 1640 53 1869 64 1867	18	700		
20 998 21 1000 22 1000 23 924 24 608 25 1441 26 1441 27 589 28 392 30 361 31 146 32 1354 33 1546 34 1547 35 1689 36 1691 38 776 38 1762 39 102 30 311 31 1541 32 1354 33 1764 34 1571 35 1680 36 1657 47 1021 48 2222 50 1282 51 1657 52 1074 53 1657 54 1657 55 1282 56 1571 57 1622 58 1657 59 2225 50 1285 51 1492 52 1076 53 1492 </th <th>19</th> <th>683</th> <th></th> <th></th>	19	683		
21 323 23 324 26 1446 27 589 28 332 30 361 31 1076 33 1644 34 1544 35 1646 36 177 37 1860 38 1102 39 1102 41 2164 42 2160 43 1860 44 2161 45 1667 46 1674 47 1222 48 2260 49 2212 50 1663 51 1665 52 1665 53 1860 64 1861 65 270 66 1681 67 2207 68 862 69 1881 66 1681 67 2037 77 1425	20	998		
24 008 25 1046 26 1047 27 589 28 332 30 31 31 1076 32 1344 33 1548 34 1541 35 1354 36 1859 373 1380 38 1744 39 1417 44 2051 454 1657 454 1657 454 1657 454 1657 454 1657 454 1657 454 1657 455 1657 456 1657 456 1657 456 1657 456 1657 456 1657 456 1657 456 1657 456 1657 457 1656 <	21	524		
	22	1009		
	23	924 698		
	25	1046		
	26	1491		
28 332 30 331 31 1076 32 1354 33 1545 33 1545 33 1545 33 1545 34 1341 35 1970 36 1970 37 1980 38 784 39 1102 40 6738 41 2201 42 4107 43 2202 44 2082 50 1867 43 2205 44 2082 50 1867 45 2652 50 1385 51 1662 52 1014 53 1860 64 1436 65 4503 65 1402 66 3145 67 3152 68 62 69 622 60 1435 <th>27</th> <th>589</th> <th></th> <th></th>	27	589		
29 382 31 1076 32 154 33 154 34 1641 35 1770 36 1880 37 1880 38 744 39 1162 40 6738 41 2161 42 4107 43 2020 44 2085 55 1857 46 1079 47 1023 48 2026 50 1286 51 1853 52 153 53 1860 54 1857 55 2870 56 1860 57 3117 58 1862 59 682 61 1851 62 2207 63 1346 64 1435 65 4503 66 2007 70 1556 <th>28</th> <th>392</th> <th></th> <th></th>	28	392		
30 361 31 1075 32 154 33 154 34 154 35 1870 36 1859 37 184 38 764 41 2161 42 4107 43 2222 44 2285 45 1557 46 1079 47 1023 48 2282 50 1286 51 1669 52 114 53 1869 54 162 55 2870 56 1460 57 3317 58 2212 59 682 61 851 62 509 63 1346 64 1498 65 4503 66 2124 67 2207 68 1581 69 158	29	392		
31 10/6 32 1544 33 1541 35 1970 36 1559 37 1880 38 774 39 1102 40 6736 41 2161 42 4107 43 2220 44 2085 45 1557 46 1075 47 1023 48 2285 15 3653 128 1286 55 2570 56 1460 57 3817 58 2212 59 682 60 8706 61 158 62 159 63 1486 64 1495 65 4503 66 2124 67 207 68 158 69 1485 69 1495 69 158 <th>30</th> <th>361</th> <th></th> <th></th>	30	361		
33 1.5.5 34 1641 35 1970 36 1899 37 1980 38 744 39 1102 40 6738 41 2161 42 4107 43 2220 44 2085 45 1667 46 1079 47 1023 48 2282 51 3633 52 3663 53 1689 54 1982 55 2270 56 1460 57 3317 58 2212 59 682 60 3706 61 1488 65 4503 65 1498 65 4503 65 4503 65 1498 65 4503 65 1505 66 1486 67 220	31	1076		
3 1541 35 1970 36 1869 37 1990 38 784 39 1102 40 6738 41 2161 42 2005 43 2220 44 2085 45 1667 46 1079 47 1023 48 2285 49 2822 50 1286 51 3663 52 1014 53 1869 54 1992 55 2870 56 480 57 3317 58 682 60 8706 61 480 62 509 63 1345 64 1498 65 4503 66 2124 67 207 73 1058 74 455 75 6822	32	1548		
35 1970 38 1980 38 784 39 1102 40 6738 41 2161 42 4107 43 2220 44 2085 45 1657 46 1079 47 1023 48 2282 50 1288 51 3663 52 1014 53 1869 54 1982 55 2670 56 1460 57 3317 58 2212 59 662 60 8776 61 1480 62 599 63 1345 64 1480 65 4503 66 2124 67 3282 70 1338 71 1173 72 1685 73 1052 74 585 </th <th>34</th> <th>1540</th> <th></th> <th></th>	34	1540		
96 1890 37 1990 38 774 39 1102 41 2161 42 4107 43 2220 44 2085 45 1667 46 1079 47 1023 48 2226 49 2225 104 53 54 1667 45 1667 46 1079 47 1023 48 2226 49 2822 104 53 55 2670 56 1400 57 3317 58 2212 59 662 60 3706 61 861 62 599 63 1345 64 1408 65 453 66 2124 67 205 73 1052 74 565	35	1970		
37 1980 38 734 40 6738 41 2161 42 4107 43 2220 44 2065 45 1857 46 1079 47 1023 48 2265 50 1288 51 3653 52 1014 53 1869 54 1962 55 2270 56 1460 57 3317 58 2212 59 682 51 1460 55 2270 56 1460 57 3317 58 2212 59 682 50 2706 51 1460 52 509 53 1345 54 1493 55 2707 56 4503 66 1493 71 1425 </th <th>36</th> <th>1859</th> <th></th> <th></th>	36	1859		
38 744 39 1102 41 2161 42 4107 43 2220 44 2065 45 1657 46 1079 47 1023 48 2265 50 1288 51 3633 52 1014 53 1869 54 1862 55 2270 56 1440 57 3317 58 2212 59 682 59 682 50 2217 58 2212 59 682 50 862 50 862 50 862 51 365 52 104 53 1465 54 1439 56 2247 57 365 58 1439 59 682 51 585	37	1980		
39 1102 41 2161 42 4107 43 2220 44 2085 45 1867 46 1073 47 1023 48 2265 49 2225 50 1288 51 3663 52 1014 53 1869 54 1962 55 2670 56 1480 57 3317 58 2212 59 682 51 3863 52 114 53 1869 54 1962 55 2212 59 682 51 3145 62 599 63 1446 64 1498 65 4503 66 2124 67 2007 68 1861 69 1439 70 1388 </th <th>38</th> <th>784</th> <th></th> <th></th>	38	784		
40 6738 41 2161 42 4107 43 2220 44 2085 45 1667 46 1079 47 1023 48 2282 50 1288 51 3863 52 1014 53 1860 54 1982 55 2270 56 1460 57 3317 58 2212 59 682 60 8706 61 851 62 509 63 1345 64 1489 65 4503 66 2124 67 2207 68 1581 69 1439 70 1368 71 1173 72 1655 73 1052 74 585 75 6822 76 805 <th>39</th> <th>1102</th> <th></th> <th></th>	39	1102		
41 2163 44 2020 44 2085 45 1657 46 1079 47 1023 48 2265 49 2822 1014 3653 51 3653 52 1014 53 1869 54 1962 55 2670 56 1460 57 3317 58 2212 59 662 60 8706 61 851 62 1345 64 1498 65 4503 66 2124 67 2207 70 138 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 1431 80 1431 81 1995<	40	6738		
42 4107 44 2085 45 1657 46 1079 47 1023 48 2822 50 1288 49 2822 50 1288 51 3653 52 1014 53 1869 54 1962 55 2670 56 1460 57 3317 58 2212 59 682 60 8706 61 851 62 509 63 1345 64 1408 65 4503 66 2124 67 207 68 1581 69 1438 64 1408 65 4503 66 1224 67 207 74 158 75 6822 76 805 77 1425	41	2161		
42 44 1057 44 1023 47 1023 48 2265 49 222 50 1288 51 3653 21014 53 54 55 2670 56 57 317 58 2212 59 60 8706 61 851 62 59 63 1345 64 1498 65 4003 66 4503 66 1358 71 1173 72 165 73 165 74 165 75 622 76 77 </th <th>42</th> <th>4107</th> <th></th> <th></th>	42	4107		
45 1657 46 1079 47 1023 48 2265 49 2822 50 1288 51 3653 52 1962 53 1899 54 1962 55 1460 56 1460 57 3317 58 2212 59 682 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 4513 67 2207 68 1543 69 1543 69 1543 69 1543 69 1543 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1558 <th>40</th> <th>2085</th> <th></th> <th></th>	40	2085		
46 1079 47 1023 48 2822 50 1288 51 3653 52 1014 53 1869 54 1962 55 2670 56 1460 57 3317 58 2212 59 682 60 8706 61 851 62 509 63 1345 64 1498 65 4224 67 2207 68 1581 65 1345 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6622 76 805 77 1558 80 14995 81 1995 </th <th>45</th> <th>1657</th> <th></th> <th></th>	45	1657		
47 1023 48 2265 50 1288 51 3653 52 1014 53 1869 54 1962 55 2670 56 1460 57 3317 58 2212 59 662 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1665 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	46	1079		
48 2265 49 2822 51 3653 52 1014 53 1869 54 1962 55 2670 56 1460 57 3317 58 2212 59 662 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1568 80 1439 81 1995 82 594	47	1023		
49 2822 50 128 51 3653 52 1014 53 1869 54 1962 55 2670 56 1460 57 3317 58 2212 59 662 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1995 82 594	48	2265		
50 1288 51 3663 52 1014 53 1869 54 1982 55 2670 56 1460 57 3317 58 2212 59 662 60 8706 61 851 62 509 63 1345 64 1488 65 4503 66 2124 67 2207 68 1581 69 1439 70 1388 71 1173 72 1665 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 584	49	2822		
3 3003 52 1014 53 1869 54 1962 55 2670 56 1460 57 3317 58 2212 59 682 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 825 77 1425 78 2037 79 1558 80 1431 81 1985 82 584	50	1288		
3 184 54 1962 55 2670 56 1460 57 3317 58 2212 59 682 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6622 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	51	3053		
54 1962 55 2670 56 1460 57 3317 58 2212 59 682 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 8262 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	53	1869		
55 2670 56 1460 57 3317 58 2212 59 682 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1425 80 1431 81 1995 82 594	54	1962		
56 1460 57 3317 58 2212 59 682 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1665 73 1052 74 885 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	55	2670		
57 3317 58 2212 59 662 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	56	1460		
38 2212 59 682 60 8706 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1665 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	57	3317		
39 062 60 8706 61 651 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 825 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	58	2212		
1 5.00 61 851 62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 825 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	59	682 8706		
62 509 63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1665 73 1052 74 585 75 6822 76 825 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	61	851		
63 1345 64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	62	509		
64 1498 65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	63	1345		
65 4503 66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	64	1498		
66 2124 67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	65	4503		
67 2207 68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	66	2124		
68 1581 69 1439 70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	67	2207		
70 1358 71 1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	68	1581		
1173 72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	70	1358		
72 1655 73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	71	1173		
73 1052 74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	72	1655		
74 585 75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	73	1052		
75 6822 76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	74	585		
76 805 77 1425 78 2037 79 1558 80 1431 81 1995 82 594	75	6822		
11 1425 78 2037 79 1558 80 1431 81 1995 82 594	76	805		
79 1558 80 1431 81 1995 82 594	77	1425		
80 1431 81 1995 82 594	78 70	2037		
81 1995 82 594	80	1431		
82 594	81	1995		
	82	594		

167	1907
168	2029
169	807
170	1440
172	634
173	1606
174	666
175	1091
176	929
177	6472
170	4271
180	1835
181	3109
182	1184
183	4194
184	979
185	1329
187	2621
188	2439
189	1482
190	567
191	1873
192	1370
193	805
195	3256
196	2456
197	1462
198	833
199	2802
200	609
202	467
203	6511
204	1964
205	3622
206	4481
207	6170
209	1925
210	1445
211	3796
212	1800
213	2695
214	1315
216	5556
217	2568
218	4248
219	2045
220	1613
222	1183
223	4323
224	2028
225	811
226	3796
228	1748
229	2163
230	1465
231	5811
232	2863
233 234	3880
235	1186
236	1469
237	804
238	1810
239	1453
240 241	3281
242	2441
243	3798
244	934

Table 4: Estimate:	s of Populati	on in the Tura	ngi Zone
	Percent of		
	Pop in		
Census District	Turangi		Population in
Regions	District	Poputaltion	Turangi
Matavera	100	762	762
Pue-Matavera	100	1096	1096
Tupapa-Maraere	100	524	524
Ngatangiia-Muri	50	939	470
Nikao-Panama	25	1269	317
Takuvaine-Parek	67	803	535
Tutakimoa-Teotu	25	390	98
Avatiu-Ruatonga	25	1066	267
Total			4068

981	Total Houses in Turangi Zone =
4.1	Average Number of People per House =
4022	Population in Turangi Zone =
11	Percent Difference % =

Table 5: Turangi Demand Pattern

	Flow (L/s)							
	Sun	Thur	Wed	Mon	Fri	Tues	Sat	
Time	23/08/92	27/08/92	9/9/92	7/9/92	4/9/92	27/10/92	24/10/92	Average
0	21	22.5	26	24.5	23.5	19	19.5	22.3
4	20.5	22	25	24	23	19	19	21.8
8	24.5	25	29	28.5	26.5	26	25.5	26.4
12	23.5	23.5	27	28	27	25	24	25.4
16	23	24.5	30.5	29	30	24.5	25.5	26.7
20	21	23	29.5	28	27.5	25	21	25.0
24	20	21	25	24	25	22.5	19	22.4
Average	21.9	23.1	27.4	26.6	26.1	23.0	21.9	24.3







Appendix D: Calibration and Model Run of the Turangi Hydraulic Model

Table 1: Summary of Calibration Scenarios

Junction/ Intake	Roughnes s Calibration Factor	Flow Calibratio n Factor	Model Pressure Head (m)	Maximum Metered Pressure Head (m)	Minimum Metered Pressue Head (m)	Percent Differenc e (%)	Model Flow (I/s)	Average Metered Flow (L/s)	Maximum Metered Flow (L/s)	Percent Differenc e (%)
Turangi Intake	1	1				C (70)	22.83	22.7	36.9	0
Matavera Intake	1	1					-0.62	14.7	26.5	2471
Tupapa Intake	1	1					5.31	19.6	35.6	269
J-191- Airport	1	1	60.27	24	14	151				
10b- Catholic Church Hydrant	1	1	61.92	26	18	138				
J-213- Empire Theather	1	1	63.2	30	18	111				
J-101- Apstalic Church	1	1	50.38	27	12	87				
Node 6- Goldie PP	1	1	61.33	50	24	23				
J-122- Ngatipa Clinic	1	1	57.61	30	26	92				
J-104- Tupapa PP	1	1	58.51	60	17	0				
J-108- Matavera PP	1	1	54.01	60	15	0				
J-124- Turangi PP	1	1	62.77	65	22	0				
J-127- Avana PP	1	1	66.52	70	25	0				

Junction/ Intake	Roughnes s Calibration Factor	Flow Calibratio n Factor	Model Pressure Head (m)	Maximum Metered Pressure Head (m)	Minimum Metered Pressue Head (m)	Percent Differenc e (%)	Model Flow (I/s)	Average Metered Flow (L/s)	Maximum Metered Flow (L/s)	Percent Differenc e (%)
Turangi Intake	1.5	2.34	()	()	. ,	()	30.6	22.7	36.9	0
Matavera Intake	1.5	2.34					16.1	14.7	26.5	0
Tupapa Intake	1.5	2.34					16.9	19.6	35.6	16
J-191- Airport	1.5	2.34	45.9	24	14	91				
10b- Catholic Church Hydran	1.5	2.34	51.43	26	18	98				
J-213- Empire Theather	1.5	2.34	52.72	30	18	76				
J-101- Apstalic Church	1.5	2.34	43.65	27	12	62				
Node 6- Goldie PP	1.5	2.34	53.26	50	24	7				
J-122- Ngatipa Clinic	1.5	2.34	49.14	30	26	64				
J-104- Tupapa PP	1.5	2.34	54.55	60	17	0				
J-108- Matavera PP	1.5	2.34	51.56	60	15	0				
J-124- Turangi PP	1.5	2.34	57.8	65	22	0				
J-127- Avana PP	1.5	2.34	61.54	70	25	0				

	Roughnes s	Flow	Model	Maximum Metered	Minimum Metered	Percent	Model	Average Metered	Maximum Metered	Percent
Junction/ Intake	Factor	n Factor	Pressure Head (m)	Pressure Head (m)	Head (m)	e (%)	Flow (I/s)	(L/s)	Flow (L/s)	e (%)
Turangi Intake	1.5	2.8					34.2	22.7	36.9	0
Matavera Intake	1.5	2.8					21	14.7	26.5	0
Tupapa Intake	1.5	2.8					20.9	19.6	35.6	0
J-191- Airport	1.5	2.8	38.33	24	14	60				
10b- Catholic Church Hydrant	t 1.5	2.8	45.98	26	18	77				
J-213- Empire Theather	1.5	2.8	47.27	30	18	58				
J-101- Apstalic Church	1.5	2.8	40.06	27	12	48				
Node 6- Goldie PP	1.5	2.8	49.02	50	24	0				
J-122- Ngatipa Clinic	1.5	2.8	44.71	30	26	49				
J-104- Tupapa PP	1.5	2.8	52.31	60	17	0				
J-108- Matavera PP	1.5	2.8	49.97	60	15	0				
J-124- Turangi PP	1.5	2.8	55.15	65	22	0				
J-127- Avana PP	1.5	2.8	58.89	70	25	0				

Junction/ Intake	Roughnes s Calibration Factor	Flow Calibratio n Factor	Model Pressure Head (m)	Maximum Metered Pressure Head (m)	Minimum Metered Pressue Head (m)	Percent Differenc e (%)	Model Flow (I/s)	Average Metered Flow (L/s)	Maximum Metered Flow (L/s)	Percent Differenc e (%)
Turangi Intake	1.5	3.1					36.7	22.7	36.9	0
Matavera Intake	1.5	3.1					24.1	14.7	26.5	0
Tupapa Intake	1.5	3.1					23.5	19.6	35.6	0
J-191- Airport	1.5	3.1	32.76	24	14	37				
10b- Catholic Church Hydrant	1.5	3.1	41.96	26	18	61				
J-213- Empire Theather	1.5	3.1	43.26	30	18	44				
J-101- Apstalic Church	1.5	3.1	37.4	27	12	39				
Node 6- Goldie PP	1.5	3.1	45.89	50	24	0				
J-122- Ngatipa Clinic	1.5	3.1	41.44	30	26	38				
J-104- Tupapa PP	1.5	3.1	50.63	60	17	0				
J-108- Matavera PP	1.5	3.1	48.76	60	15	0				
J-124- Turangi PP	1.5	3.1	53.19	65	22	0				
J-127- Avana PP	1.5	3.1	56.93	70	25	0				

	Roughnes s Calibration	Flow Calibratio	Model Pressure	Maximum Metered Pressure	Minimum Metered Pressue	Percent Differenc	Model Flow	Average Metered Flow	Maximum Metered Flow	Percent Differenc
Junction/ Intake	Factor	n Factor	Head (m)	Head (m)	Head (m)	e (%)	(l/s)	(L/s)	(L/s)	e (%)
Turangi Intake	1.5	3.51					40.3	22.7	36.9	8
Matavera Intake	1.5	3.51					28.2	14.7	26.5	6
Tupapa Intake	1.5	3.51					27	19.6	35.6	0
J-191- Airport	1.5	3.51	24.35	24	14	1				
10b- Catholic Church Hydrant	1.5	3.51	35.88	26	18	38				
J-213- Empire Theather	1.5	3.51	37.18	30	18	24				
J-101- Apstalic Church	1.5	3.51	33.36	27	12	24				
Node 6- Goldie PP	1.5	3.51	41.14	50	24	0				
J-122- Ngatipa Clinic	1.5	3.51	36.49	30	26	22				
J-104- Tupapa PP	1.5	3.51	48.07	60	17	0				
J-108- Matavera PP	1.5	3.51	46.9	60	15	0				
J-124- Turangi PP	1.5	3.51	50.22	65	22	0				
J-127- Avana PP	1.5	3.51	53.96	70	25	0				

Junction/ Intake	Roughnes s Calibration Factor	Flow Calibratio n Factor	Model Pressure Head (m)	Maximum Metered Pressure Head (m)	Minimum Metered Pressue Head (m)	Percent Differenc e (%)	Model Flow (I/s)	Average Metered Flow (L/s)	Maximum Metered Flow (L/s)	Percent Differenc e (%)
Turangi Intake	1.5	3.51					40.3	22.7	36.9	8
Matavera Intake	1.5	3.51					28.2	14.7	26.5	6
Tupapa Intake	1.5	3.51					27	19.6	35.6	0
J-191- Airport	1.5	3.51	24.35	24	14	1				
10b- Catholic Church Hydrant	1.5	3.51	35.88	26	18	38				
J-213- Empire Theather	1.5	3.51	37.18	30	18	24				
J-101- Apstalic Church	1.5	3.51	33.36	27	12	24				
Node 6- Goldie PP	1.5	3.51	41.14	50	24	0				
J-122- Ngatipa Clinic	1.5	3.51	36.49	30	26	22				
J-104- Tupapa PP	1.5	3.51	48.07	60	17	0				
J-108- Matavera PP	1.5	3.51	46.9	60	15	0				
J-124- Turangi PP	1.5	3.51	50.22	65	22	0				
J-127- Avana PP	1.5	3.51	53.96	70	25	0				

Table 2: Summary of Model Run

	Roughnes s Calibration	Flow Calibratio	Model Pressure	Average Metered Pressure	Minimum Metered Pressue	Percent Differenc	Model Flow	Average Metered Flow	Maximum Metered Flow	Percent Differenc
Junction/ Intake	Factor	n Factor	Head (m)	Head (m)	Head (m)	e (%)	(l/s)	(L/s)	(L/s)	e (%)
Turangi Intake	1.5	2.8					76.2	22.7	36.9	52
Matavera Intake	1.5	2.8					-	14.7	26.5	
Tupapa Intake	1.5	2.8					-	19.6	35.6	
J-191- Airport	1.5	2.8	-0.79	22	14	106				
10b- Catholic Church Hydrant	1.5	2.8	6.86	23	18	62				
J-213- Empire Theather	1.5	2.8	8.16	25	18	55				
J-101- Apstalic Church	1.5	2.8	-0.76	17	12	106				
Node 6- Goldie PP	1.5	2.8	9.27	27	24	66				
J-122- Ngatipa Clinic	1.5	2.8	6.95	28	26	73				
J-104- Tupapa PP	1.5	2.8	9.43	40.6	17	45				
J-108- Matavera PP	1.5	2.8	13.01	40.2	15	13				
J-124- Turangi PP	1.5	2.8	22.97	48	22	0				
J-127- Avana PP	1.5	2.8	26.71	58	25	0				

Table 3: Pressure Distribution along Turangi Zone for Different Demand Factors

	Mesured Pressure	(Base) Model Pressure	(2.34x) Model Pressure	(2.8x) Model Pressure	(3.1x) Model Pressure	(3.51x) Model Pressure
Junction/ Intake	Head (m)	Head (m)	Head (m)	Head (m)	Head (m)	Head (m)
J-191- Airport	22	60.27	45.9	38.33	32.76	24.35
10b- Catholic Church Hydrant	23	61.92	51.43	45.98	41.96	35.88
J-213- Empire Theather	25	63.2	52.72	47.27	43.26	37.18
J-101- Apstalic Church	17	50.38	43.65	40.06	37.4	33.36
Node 6- Goldie PP	31.5	61.33	53.26	49.02	45.89	41.14
J-122- Ngatipa Clinic	28	57.61	49.14	44.71	41.44	36.49
J-104- Tupapa PP	40.6	58.51	54.55	52.31	50.63	48.07
J-108- Matavera PP	40.2	54.01	51.56	49.97	48.76	46.9
J-124- Turangi PP	48	62.77	57.8	55.15	53.19	50.22
J-127- Avana PP	58	66.52	61.54	58.89	56.93	53.96





















Appendix E: List of Tasks

List of Tasks for the Rarotonga Water Works

- 1. Become more familiar with Cybernet by doing the tutorials.
- 2. Update the Cybernet master layout of Rarotonga previously done by SOPAC \rightarrow check layout, pipe material and size
 - The Project East updates that were done on the Turangi model will have to be incorporated into this file
 - Master plan file is Patric:C:\waterdata\something???
- 3. Use MapInfo to create a database link with Cybernet in order to update the demands at each node
 - Count the number and type (domestic, industrial, commercial, institutional, hotel, agricultural) of users at each node→ because of Rarotonga's small size this could be done for each individual user
- 4. Metered demands from over 60 commercial, industrial and institutional locations should be input directly into their nearest respective junctions
 - Exact locations of these sites should be gathered using your GPS equipment and input into MapInfo, the demand data can then be attributed to each specific location, and this information transferred over to Cybernet
- 5. Create a network model for each zone as proposed by the Asian Development Bank, like the Turangi zone done in this report→ calibrate the models and see how they perform
- 6. Model improvements the Water Works Department are planning to make to the southwest section of the Rarotonga water distribution system→ see how it performs
- 7. Create a combined demand pattern for each intake. As you go through the records for each intake, keep a note of the maximum and minimum flows during this period→ these values can be used to calibrate the model. Method is the same as for the Turangi demand pattern that was created→ have data for each day of the week, don't choose records where the pattern is wacked or just a constant line
- 8. Find out where the valves are in your system, and how they operate→ if they're just open all the time, don't include them in the Cybernet model, but if they open and close during certain times of the day find out when, where, etc and add information to the model
- 9. Use GPS equipment to check exact elevations (and locations) of intakes and tanks→input information into Cybernet model
- 10. Go around and check all the meters in existence in Rarotonga (domestic, commercial, at intakes) and see if any of them are still working→ if they are, start collecting data, if not, see if they can be fixed and start collecting data
- 11. Collect flow data from intakes so you can know how much water is being used in Rarotonga→ make estimates on leakage amounts once known use is estimated
- 12. Collect hourly flow data (or almost hourly flow data) from different locations to develop specific user demand patterns for domestic, hotel, agricultural, industrial, institutional, and commercial users→ this could be quite easy if some of those old meters are still working
- 13. Run the Cybernet model once the information in it is as accurate as possible (or even before), and compare the pressure, flow, velocity, etc. values to those measured out in the field

- The model can be used as a guide to pinpoint problems, and to do checks on the distribution system
 - ➤ Checking pressures along galvanized iron pipes to see if there are leaks→ simply measure pressure at household hose cocks along the pipe line to plot the hydraulic gradient- a sudden change in the slope (reduction of pressure head) of the HGL may indicate the approximate location of a leak
 - Locating areas to put in PRV or PSV
 - Intakes that have water flowing back up to them
 - Pipes where there is no flow during peak demand, or that have negative pressures and are possibly back-drawing contaminants into the distribution system
- 14. If the location of pipe bends, fittings, reducers, etc. are known, the associated minor loss values can be added to the appropriate pipes in the Cybernet model (this is really refining your model)
- 15. Locate leaks in the system and repair \rightarrow to reduce total demand in Rarotonga
- 16. Input information collected into MapInfo to create a Water Utilities Data Base. Will be able to organize data, perform asset management, etc.






